

Email/Fax

PC no. 116

CIN: U40109RJ2000SGC016486

JAIPUR VIDYUT VITRAN NIGAM LIMITED
OFFICE OF THE SUPERINTENDING ENGINEER (PLAN & MONTG.)

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.

Telephone & Fax No. 0141-2747206, E-mail: seplan@jvvn.org

No. JPD/SE (Plan & Montg.)/AEN(33KV works)/D. 1409

Jaipur, Dated: 01/10/2018

The Superintending Engineer (O&M),
Jaipur Discom,
Alwar.

**Sub:- Administrative approval for 4 nos. 33 KV I/C's from 220 KV GSS
Ramnagar Bansur, Distt.- Alwar.**

Ref: - 1) Your office letter no. 4969 dated 28.08.2018.

In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of CMD as per item 2(b) of D.O.P, for the following 33 KV works.

- i) Erection of 1.8 KM D/C O/H 33 KV line on ACSR Dog Conductor from 220 KV GSS Ramnagar Bansur to 33 KV Loyati feeder at a distance of 5.5 KM from 33/11 KV S/S Ishara Ka Bas.
- ii) Erection of 2.9 KM D/C O/H 33 KV line on ACSR Dog Conductor plus laying of 0.3 KM S/C 3x300 SQmm. XLPE U/G cable from 220 KV GSS Ramnagar Bansur to 33 KV Gunta feeder at a distance of 3.5 KM from 132 KV GSS Bansur.
- iii) Erection of 2 KM S/C O/H 33 KV line on ACSR Dog Conductor from T-point of 33 KV Harsora feeder at a distance of 3.5 Km from 132 KV GSS Bansur to 33 KV Harsora feeder at a distance of 3.0 KM from 33/11 KV S/S Babriya to bifurcate 33/11 KV S/S Babriya from 33 KV Harsora feeder.

Note: -

1. (i) The new proposed 33 KV Ishara Ka Bas feeder will supply 33/11 KV S/S Ishara Ka Bas, (ii) 33 KV Loyati feeder will supply 33/11 KV S/Ss Loyati and Nangal lakha, (iii) 33 KV Gunta feeder will supply 33/11 KV S/Ss Gunta, Mothuka and Kalyan Nagar & (iv) 33 KV Harsora feeder will supply 33/11 KV S/Ss Harsora and Devsan. (v) The remaining 33 KV Babriya feeder will supply 33/11 KV S/S Babriya.
2. No existing 33 KV line will be dismantled.
3. The above works are included in APP 2018-19 under ST Plan.




(S.P. Gupta)

Superintending Engineer
(Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The ACE (PPM), Jaipur Discom, Jaipur.
2. The Zonal Engineer (J/Z), Jaipur Discom, Jaipur.
3. The Superintending Engineer (TW), Jaipur Discom, Jaipur.
4. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
5. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
6. The P.A. to SE (Plan), Jaipur Discom, Jaipur.



Superintending Engineer
(Plan & Montg.)