

Email/Fax

CIN: U40109RJ2000SGC016486

JAIPUR VIDYUT VITRAN NIGAM LIMITED

OFFICE OF THE SUPERINTENDING ENGINEER (PLAN & MONTG.)

Vidyut bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.

Telephone & Fax No. 0141-2747206, E-mail:seplan.jvvn@gmail.com

NO.JPD/SE (PLAN)/AEN (33KV works)/D. 506 JAIPUR, DATED: 4/4/18

The Superintending Engineer (O&M),
Jaipur Discom,
Alwar.

Sub:- Regarding technical sanction of the estimates for bifurcation of 33 KV Rathibar feeder from 220 KV GSS Khushkheda.

Ref:- Your office note sheet No. 12297 dated 23.03.2018..

In context to above, it is to intimate that the proposal sent by you has been examined and it is to intimate that after proposal remaining 33 KV SICPA feeder and Rathibar feeder remain overloaded. Therefore, it is requested to please shift some load from overloaded feeders to other under loaded feeders or explore possibilities of creation of other new 33 KV feeders.


Therefore, it is requested to reply of observation at earliest through Zonal Chief Engineer (J/Z), so that further needful action may be taken by this office.



(S.P. Gupta)

**Superintending Engineer
(Plan & Montg.)**

Copy submitted to Zonal Chief Engineer (J/Z), Jaipur Discom, Jaipur for information and necessary action.



**Superintending Engineer
(Plan & Montg.)**