

JAIPUR VIDYUT VITRAN NIGAM LIMITED
OFFICE OF THE SUPERINTENDING ENGINEER (PLAN & MONTG.)

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.
Telephone & Fax No. 0141-2747206, E-mail:seplan.jvvn@gmail.com

No. JPD/SE (Plan)/AEN(33KV works)/D. 510

Jaipur, Dated: 5/4/18

The Superintending Engineer (O&M),
Jaipur Discom,
Alwar.

Sub:- **Administrative approval for erection of 14.2 KM line from 132 KV GSS Ramgarh to 33/11 KV S/S Neekach to shift 33/11 KV S/S Mubarikpur and pata from 33 KV Mubarikpur feeder to 33 KV Neekach feeder, under AEN (O&M), JPD, Ramgarh, Distt. - Alwar.**


Ref: - 1) Your office note sheet no.11577 dated 07.03.2018.

In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of MD as per item 2(b) of D.O.P, for the following 33 KV works.

- (i) Erection of 14.2 KM 33 KV S/C O/H line on ACSR Dog Conductor from 132 KV GSS Ramgarh to 33/11 KV S/S Neekach.


Note 1: The 33/11 KV S/S Nangal Nangli & Neekach will remain on new proposed 33 KV Neekach feeder & the 33/11 KV S/S Mubarikpur and Pata will be on 33 KV Mubarikpur feeder.

2: The above work will be carried out under DDUGJY scheme under APP 2018-19.


(S.P. Gupta)
Superintending Engineer
(Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The Zonal Chief Engineer (J/Z), Jaipur Discom, Jaipur.
2. The Superintending Engineer (TW), Jaipur Discom, Jaipur.
3. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
4. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
5. The P.A. to SE (Plan), Jaipur Discom, Jaipur.


Superintending Engineer 5.4.18
(Plan & Montg.)