

JAIPUR VIDYUT VITRAN NIGAM LIMITED
OFFICE OF THE SUPERINTENDING ENGINEER (PLAN & MONTG.)

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.
Telephone & Fax No. 0141-2747206, E-mail:seplan.jvvn@gmail.com

No. JPD/SE (Plan)/AEN(33KV works)/D. 704

Jaipur, Dated: 21/5/2018

The Superintending Engineer (O&M),
Jaipur Discom,
Kota.


Sub:- Ex-post facto administrative approval for erection of 33 KV line for 33/11 KV S/S Kotda Deep Singh, Distt. - Kota.

Ref: - 1) This office letter no. 160 (PC-43) dated 20.02.2013.
2) Your office letter no. 7550 dated 27.02.2018.

In consideration of the proposal furnished vide letter under reference, I am directed to convey the ex-post facto administrative approval of MD as per item 2(b) of D.O.P, for the following 33 KV works.


- (i) Erection of 6.5 km. 33 KV S/C O/H line on ACSR Dog conductor T-off from 33 KV Budhadeet feeder at a distance of 4.0 KM from 33/11 KV S/S Budhadeet to 33/11 KV S/S Kotda Deep Singh in place of previously sanctioned 4.0 KM 33 KV S/C O/H line.

Note: - The earlier approval for point no. 03 [Erection of 4.0 KM 33 KV S/C O/H line with ACSR Dog Conductor from Barod to Kotda Deep Singh S/S.] of this office letter no. 160 (PC no. 43) dated 20.02.2013 is hereby withdrawn.


Superintending Engineer
(Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The ACE (PPM), Jaipur Discom, Jaipur.
2. The Zonal Engineer (K/Z), Jaipur Discom, Kota.
3. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
4. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
5. The P.A. to SE (Plan), Jaipur Discom, Jaipur.


Superintending Engineer
(Plan & Montg.)