

Email/Fax

PC no. 53

CIN: U40109RJ2000SGC016486

JAIPUR VIDYUT VITRAN NIGAM LIMITED
OFFICE OF THE SUPERINTENDING ENGINEER (PLAN & MONTG.)

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.
Telephone & Fax No. 0141-2747206, E-mail:seplan.jvvn@gmail.com

No. JPD/SE (Plan)/AEN(33KV works)/D. 708

Jaipur, Dated: 21/5/2018

The Superintending Engineer (JCC),
Jaipur Discom,
Jaipur.


Sub:- Administrative approval for bifurcation of load of 33 KV RPA-I feeder from
132 KV GSS VKIA, Distt.- Jaipur.

Ref: - ZCE (O&M-J/Z) office note sheet no. JCC/8 dated 26.04.2018.

In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of MD as per item 2(b) of D.O.P, for the following 33 KV works:-


- (i) Laying of 0.30 KM. 3x300 SQmm. 33 KV XLPE U/G cable from 132 KV GSS VKIA to existing 33 KV Road no. 13 feeder to bifurcate load of RPA-I feeder from Road no. 13 feeder..

Note: 1) The above works are included in Annual Phase Programme 2018-19, under IPDS scheme.


Superintending Engineer
(Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The ACE (PPM), Jaipur Discom, Jaipur.
2. The Zonal Engineer (J/Z), Jaipur Discom, Jaipur.
3. The Superintending Engineer (TW), Jaipur Discom, Jaipur.
4. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
5. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
6. The P.A. to SE (Plan), Jaipur Discom, Jaipur.


Superintending Engineer
(Plan & Montg.)