

Email/Fax

PC no.....

59

CIN: U40109RJ2000SGC016486

**JAIPUR VIDYUT VITRAN NIGAM LIMITED**  
**OFFICE OF THE SUPERINTENDING ENGINEER (PLAN & MONTG.)**

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.  
Telephone & Fax No. 0141-2747206, E-mail:seplan.jvvn@gmail.com

No. JPD/SE (Plan)/AEN(33KV works)/D. 797 Jaipur, Dated: 5/6/18

The Superintending Engineer (O&M),  
Jaipur Discom,  
Kota.


Sub:- Administrative approval for interconnection of 33 KV Kundanpur feeder emanating from 132 KV GSS Sangod, Distt. - Kota.

Ref: - 1) Your office letter no. 1048 dated 16.05.2018.

In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of MD as per item 2(b) of D.O.P, for the following 33 KV works.


- (i) Erection of 9.1 km. 33 KV S/C O/H line on ACSR Dog conductor from 33/11 KV S/S Vinod Khurd to 33/11 KV S/S Mandap.

Note: - The 33 KV Kundanpur feeder emanating from 132 KV GSS Sangod will cater the load of 33/11 KV S/Ss Kundanpur & Adusa; 33 KV Mandap feeder emanating from 132 KV GSS Deoli will cater the load of 33/11 KV S/Ss Mandap, Lalaheda & Vinod Khurd.

  
Superintending Engineer  
(Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The ACE (PPM), Jaipur Discom, Jaipur.
2. The Zonal Engineer (K/Z), Jaipur Discom, Kota.
3. The Superintending Engineer (TW), Jaipur Discom, Jaipur.
4. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
5. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
6. The P.A. to SE (Plan), Jaipur Discom, Jaipur.

  
Superintending Engineer  
(Plan & Montg.)