

Email/Fax

PC no. 80

CIN: U40109RJ2000SGC016486

JAIPUR VIDYUT VITRAN NIGAM LIMITED
OFFICE OF THE SUPERINTENDING ENGINEER (PLAN & MONTG.)

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.
Telephone & Fax No. 0141-2747206, E-mail:seplan.jvvn@gmail.com

No. JPD/SE (Plan)/AEN(33KV works)/D. 1084

Jaipur, Dated: 19/07/2018

The Superintending Engineer (O&M),
Jaipur Discom,
Alwar.

Sub:- Administrative approval for bifurcation of 33 KV Baroda Meo feeder emanating from 132 KV GSS Laxmangarh, Distt.- Alwar.

Ref: - Your office letter no. 2699 dated 28.06.2018.

In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of MD as per item 2(b) of D.O.P, for the following 33 KV works:-

- (i) Erection of 9.5 Km S/C O/H line with ACSR Dog conductor from 132 KV GSS Govindgarh to existing 33/11 KV S/S Baroda Meo.

Note: 1) After execution of proposed bifurcation work, proposed 33 KV Baroda Meo feeder emanating from 132 KV GSS Govindgarh will feed 33/11 KV S/S Baroda Meo and 33 KV Butiyana feeder emanating from 132 KV GSS Laxmangarh will feed 33/11 KV S/Ss Butiyana & Dusraheda.

- 2) The above works are included under ST plan in APP 2018-19.

[Handwritten Signature]

Superintending Engineer
(Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The ACE (PPM), Jaipur Discom, Jaipur.
2. The Zonal Engineer (J/Z), Jaipur Discom, Jaipur.
3. The Superintending Engineer (TW), Jaipur Discom, Jaipur.
4. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
5. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
6. The P.A. to SE (Plan), Jaipur Discom, Jaipur.

[Handwritten Signature] 19.7.18

Superintending Engineer
(Plan & Montg.)