

Email/Fax

PC no.. 98

CIN: U40109RJ2000SGC016486

JAIPUR VIDYUT VITRAN NIGAM LIMITED
OFFICE OF THE SUPERINTENDING ENGINEER (PLAN & MONTG.)

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.
Telephone & Fax No. 0141-2747206, E-mail:seplan.jvvn@gmail.com

No. JPD/SE (Plan & Montg.)/AEN(33KV works)/D. 1240

Jaipur, Dated: 24/8/18

The Superintending Engineer (O&M),
Jaipur Discom,
Baran.

Sub:- Administrative approval for bifurcation of 33 KV Maytha feeder emanating from 132 KV GSS Atru, P.S.-Atru, Distt. - Baran.

Ref: - 1) Your office letter no. 2272 dated 24.07.2018.

In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of CMD as per item 2(b) of D.O.P, for the following 33 KV works.

- (i) Erection of 15.8 KM S/C O/H line with ACSR Dog Conductor from 132 KV GSS Atru to existing 33/11 KV S/S Maytha.

Note: -

1. After execution of proposed bifurcation work, proposed 33 KV Maytha feeder emanating from 132 KV GSS Atru will feed 33/11 KV S/S Maytha and 33 KV Sakatpur feeder emanating from 132 KV GSS Atru will feed 33/11 KV S/Ss Sakatpur & Kunjed.
2. The above works are included in APP 2018-19 under ST Plan.

SPG

(S.P. Gupta)

Superintending Engineer
(Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The ACE (PPM), Jaipur Discom, Jaipur.
2. The Zonal Engineer (K/Z), Jaipur Discom, Kota.
3. The Superintending Engineer (TW), Jaipur Discom, Jaipur.
4. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
5. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
6. The P.A. to SE (Plan), Jaipur Discom, Jaipur.

SPG

24.8.18
Superintending Engineer
(Plan & Montg.)