

JAIPUR VIDYUT VITRAN NIGAM LIMITED
OFFICE OF THE SUPERINTENDING ENGINEER (PLAN & MONTG.)

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.
 Telephone & Fax No. 0141-2747206, E-mail:seplan.jvvn@gmail.com

No. JPD/SE (Plan)/AEN(33KV works)/D. 677

Jaipur, Dated: 15/5/18

The Superintending Engineer (O&M),
 Jaipur Discom,
 Alwar.


Sub:- Administrative approval for bifurcation of load of 33 KV Maliyar Jat & Bhindusi feeder emanating from 132 KV GSS Tijara, under AEN (O&M), JPD, Tijara, Distt. - Alwar.

Ref: - 1) Your office letter no.674 dated 24.04.2018.

In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of MD as per item 2(b) of D.O.P, for the following 33 KV works.


- (i) Erection of 2.9 KM 33 KV S/C O/H line on ACSR Dog Conductor from 132 KV GSS Tijara to 33/11 KV S/S Khalilpuri + 2.7 Km 33 KV S/C O/H line on ACSR Dog Conductor T-off from proposed 33 KV Khalilpuri feeder at a distance of 0.8 km from 132 KV GSS Tijara to existing Bhindusi feeder at a distance of 5.3 Km before 33/11 S/S Bhindusi.

Note : The above works will be carried out under DDUGJY scheme.


 Superintending Engineer
 (Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The ACE (PPM), Jaipur Discom, Jaipur.
2. The Zonal Engineer (J/Z), Jaipur Discom, Jaipur.
3. The Superintending Engineer (TW), Jaipur Discom, Jaipur.
4. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
5. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
6. The P.A. to SE (Plan), Jaipur Discom, Jaipur.


 Superintending Engineer
 (Plan & Montg.)