

JAIPUR VIDYUT VITRAN NIGAM LIMITED
OFFICE OF THE SUPERINTENDING ENGINEER (PLAN & MONTG.)

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.
 Telephone & Fax No. 0141-2747206, E-mail:seplan.jvvn@gmail.com

No. JPD/SE (Plan & Montg.)/AEN(33KV works)/D. 834 Jaipur, Dated: 12/6/2018

The Superintending Engineer (O&M),
 Jaipur Discom,
 Alwar.

Sub:- Administrative approval for bifurcation of load of existing 33 KV Bhanokar feeder emanating from 132 KV GSS Laxmangarh under AEN (O&M) JPD, Kathumer, Distt. - Alwar.

Ref: - 1) Your office note sheet no. 1392 dated 21.05.2018.

In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of MD as per item 2(b) of D.O.P, for the following 33 KV works.

- (i) Erection of 11.2 KM 33 KV S/C O/H line on ACSR Dog conductor from 33/11 KV S/S Dholagarh which is on 33 KV Bhanokar feeder emanating from 132 KV GSS Laxmangarh to 33/11 KV S/S Seetaram Nagla which is emanating from 132 KV GSS Kherli.

Note: - After the proposed interconnection work, 33 KV Bhanokar feeder from 132 KV GSS Laxmangarh will feed 33/11 KV S/Ss Jatwada & Bhanokar and 33 KV Seetaram Nagla feeder from 132 KV GSS Kherli will feed 33/11 KV S/S Seetaram Nagla & 33/11 KV S/S Dholagarh.

S.P. Gupta

(S.P. Gupta)

Superintending Engineer
(Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The ACE (PPM), Jaipur Discom, Jaipur.
2. The Zonal Engineer (J/Z), Jaipur Discom, Jaipur.
3. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
4. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
5. The P.A. to SE (Plan), Jaipur Discom, Jaipur.

S.P. Gupta 12.6.18

Superintending Engineer
(Plan & Montg.)