

JAIPUR VIDYUT VITRAN NIGAM LIMITED
OFFICE OF THE SUPERINTENDING ENGINEER (PLAN & MONTG.)

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.
 Telephone & Fax No. 0141-2747206, E-mail:seplan.jvvn@gmail.com

No. JPD/SE (Plan & Montg.)/AEN(33 KV works)/D. 836 Jaipur, Dated: 12/6/2018

The Superintending Engineer (JPDC),
 Jaipur Discom,
 Jaipur.

Sub:- Revised administrative approval for sanction of 33 KV I/C from 132 KV GSS Bilwadi to 33/11 KV S/S Viratnagar under AEN (O&M) JPD, Viratnagar, Distt. - Jaipur (JPDC).

Ref: - 1) Your office letter no. 2090 dated 28.05.2018.

In consideration of the proposal furnished vide letter under reference, I am directed to convey the revised administrative approval of MD as per item 2(b) of D.O.P, for the following 33 KV works.

- (i) Erection of 7.9 KM 33 KV S/C O/H line on ACSR Dog conductor plus laying of 3.035 KM 33 KV S/C 3x300 SQmm. XLPE U/G cable (in Town area) plus laying of 0.080 KM 33 KV D/C 3x300 SQmm, XLPE U/G cable (road crossing) from 132 KV GSS Bilwadi to 33/11 KV S/S Viratnagar.

Note: - The earlier approval issued vide this office letter no. 828 (PC-46) dated 25.07.2013 in reference to 33 KV I/C from 132 KV GSS Bilwadi to 33/11 KV S/S Viratnagar is hereby withdrawn.

S.P. Gupta

Superintending Engineer
(Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The ACE (PPM), Jaipur Discom, Jaipur.
2. The Zonal Engineer (J/Z), Jaipur Discom, Jaipur.
3. The Superintending Engineer (JI), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
4. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
5. The P.A. to SE (Plan), Jaipur Discom, Jaipur.

S.P. Gupta 12.6.18
 Superintending Engineer
(Plan & Montg.)