

Email/Fax

PC no. 78

CIN: U40109RJ2000SGC016486

JAIPUR VIDYUT VITRAN NIGAM LIMITED
OFFICE OF THE SUPERINTENDING ENGINEER (PLAN & MONTG.)

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.
Telephone & Fax No. 0141-2747206, E-mail:seplan.jvvn@gmail.com

No. JPD/SE (Plan & Montg.)/AEN(33KV works)/D, 1081

Jaipur, Dated: 19/7/2018

The Superintending Engineer (O&M),
Jaipur Discom,
Alwar.

Sub:- Revised administrative approval for creation of 33/11 KV S/S Mundana Bhiwadi, P.S. Tijara, Distt. Alwar

Ref: - 1) SE (O&M), Alwar office note sheet no. 2086 dated 08.06.2018.

In consideration of the proposal furnished vide letter under reference, I am directed to convey the revised administrative approval of MD as per item 2(b) of D.O.P, for the following 33 KV works.

- (i) Creation of 1x5.0 MVA, 33/11 KV S/S at Mundana, Distt.- Alwar with 3 nos. 11 KV outgoing feeders.
- (ii) Laying of 2.35 KM 3x300 Sqmm. 33 KV S/C U/G XLPE cable from 33/11 KV S/S Kahrani-I on 33 KV Chopanki-I feeder emanating from 220 KV GSS Bhiwadi to proposed S/S Mundana.

Note: -


1. The earlier administrative approval issued vide this office letter no. 866 (PC-32) dated 05.10.2017 is hereby withdrawn.
2. The above works are included in IPDS scheme in APP 2018-19.


(S.P. Gupta)

Superintending Engineer
(Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The ACE (PPM), Jaipur Discom, Jaipur.
2. The Zonal Engineer (J/Z), Jaipur Discom, Jaipur.
3. The Superintending Engineer (TW), Jaipur Discom, Jaipur.
4. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
5. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
6. The P.A. to SE (Plan), Jaipur Discom, Jaipur.


Superintending Engineer
(Plan & Montg.)
19.7.18