

**JAIPUR VIDYUT VITRAN NIGAM LIMITED**  
**OFFICE OF THE SUPERINTENDING ENGINEER (PLAN & MONTG.)**

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.  
 Telephone & Fax No. 0141-2747206, E-mail:seplan.jvvn@gmail.com

No. JPD/SE (Plan)/AEN(33KV works)/D. 1082

Jaipur, Dated: 19/7/2018

The Superintending Engineer (O&M),  
 Jaipur Discom,  
 Alwar.


**Sub:- Revised administrative approval for creation of 1x5.0 MVA 33/11 KV S/S  
 UIT Sector no. 9 Bhiwadi, PS. Tijara, Distt. Alwar (Under IPDS Scheme).**

Ref: - Your office note sheet no. 2085 dated 08.06.2018.

In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of MD as per item 2(b) of D.O.P, for the following 33 KV works:-


- (i) Creation of 1x5.0 MVA 33/11 KV S/S at UIT Sector no. 9 Bhiwadi, PS. Tijara, Distt. Alwar with 3 nos. 11 KV outgoing feeders.
- (ii) Laying of 1.9 Km 3x300 Sqmm. 33 KV S/C U/G XLPE cable from 132 KV GSS Baba Mohan Ram Temple to proposed 33/11 KV S/S UIT Sector no. 9 Bhiwadi.

- Note: 1) The earlier administrative approval issued vide this office letter no. 910 (PC-37) dated 11.10.2017 is hereby withdrawn.  
 2) The above works are included in IPDS scheme in APP 2018-19.

  
 (S.P. Gupta)  
 Superintending Engineer  
 (Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The ACE (PPM), Jaipur Discom, Jaipur.
2. The Zonal Chief Engineer (J/Z), Jaipur Discom, Jaipur.
3. The Superintending Engineer (TW), Jaipur Discom, Jaipur.
4. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
5. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
6. The P.A. to SE (Plan), Jaipur Discom, Jaipur.

  
 Superintending Engineer  
 (Plan & Montg.)