

**JAIPUR VIDYUT VITRAN NIGAM LIMITED**  
**OFFICE OF THE SUPERINTENDING ENGINEER (PLAN & MONTG.)**

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.  
 Telephone & Fax No. 0141-2747206, E-mail:seplan.jvvn@gmail.com

No. JPD/SE (Plan)/AEN(33KV works)/D. 1132 Jaipur, Dated: 27/07/2018

The Superintending Engineer (O&M),  
 Jaipur Discom,  
 Alwar.

**Sub:- Administrative approval for creation of 33/11 KV S/S at Sonkh, PS.-  
 Kathumar, Distt. Alwar.**

Ref: - ZCE (O&M-JZ) office letter no. 1290 dated 09.07.2018.

In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of CMD as per item 2(b) of D.O.P, for the following 33 KV works:-

- (i) Creation of 1x5.0 MVA, 33/11 KV S/S at Sonkh, PS.- Kathumer, Distt. Alwar with 5 no. 11 KV outgoing feeder.
- (ii) Erection of 17.01 km. 33 KV S/C O/H line on ACSR Dog conductor from 132 KV GSS Bhadangarhi (Kherli) to proposed S/S at Sonkh.

Note:-

- 1) 1x5.0 MVA power transformer will be shifted from <sup>Existing</sup> 33/11 KV S/S Kathumer to proposed 33/11 KV S/S Sonkh.
- 2) The above works are included under ST Plan in APP 2018-19.

S.P. Gupta  
 (S.P. Gupta)  
 Superintending Engineer  
 (Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The ACE (PPM), Jaipur Discom, Jaipur.
2. The Zonal Chief Engineer (J/Z), Jaipur Discom, Jaipur.
3. The Superintending Engineer (TW), Jaipur Discom, Jaipur.
4. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
5. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
6. The P.A. to SE (Plan), Jaipur Discom, Jaipur.

S.P. Gupta 27.7.18  
 Superintending Engineer  
 (Plan & Montg.)