

JAIPUR VIDYUT VITRAN NIGAM LIMITED
OFFICE OF THE SUPERINTENDING ENGINEER
(PLAN & MONTG.)

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.
Telephone & Fax No. 0141-2747206, E-mail:seplan.jvvn@gmail.com

No. JPD/SE (Plan & Montg.)/AEN(33KV works)/D. 1213 Jaipur, Dated: 14-8-18

The Superintending Engineer (O&M),
Jaipur Discom,
Alwar.


Sub:- Administrative approval for providing alternate source of 33 KV supply to 33/11 KV S/S UIT Sector-9 Bhiwadi from 33/11 KV S/S Parsvnath, Distt.- Alwar. (under IPDS scheme)

Ref: - SE (O&M), Alwar office letter no. 4116 dated 03.08.2018.

In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of CMD as per item 2(b) of D.O.P, for the following 33 KV works:-


- (i) Laying of 2.0 KM 33 KV S/C 3x300 Sq.mm. XLPE U/G cable from 33/11 KV S/S Parsvnath having incoming 33 KV supply from 132 KV GSS Bhiwadi to 33/11 KV S/S UIT Sector-9 Bhiwadi having 33 KV supply from 132 KV GSS Baba Mohan Ram temple as an alternate source of supply.

Note: The above works are included under IPDS scheme in APP 2018-19.


(S.P. Gupta)
Superintending Engineer
(Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The ACE (PPM), Jaipur Discom, Jaipur.
2. The Zonal Engineer (J/Z), Jaipur Discom, Jaipur.
3. The Superintending Engineer (TW), Jaipur Discom, Jaipur.
4. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
5. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
6. The P.A. to SE (Plan), Jaipur Discom, Jaipur.


Superintending Engineer
(Plan & Montg.)
14-8-18