

Email/Fax

PC no. 30

CIN: U40109RJ2000SGC016486

**JAIPUR VIDYUT VITRAN NIGAM LIMITED**  
**OFFICE OF THE SUPERINTENDING ENGINEER (PLAN & MONTG.)**

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.  
Telephone & Fax No. 0141-2747206, E-mail:seplan.jvvn@gmail.com

No. JPD/SE (Plan)/AEN(33KV works)/D. 620

Jaipur, Dated: 30/4/2018

The Superintending Engineer (O&M),  
Jaipur Discom,  
Karauli.


Sub:- Administrative approval for 33 KV I/C from 132 KV GSS Karauli to existing 33 KV Karsai feeder from 132 KV GSS Kailadevi, Distt.- Karauli.

Ref: - Your office letter no. 40 dated 06.04.2018.

In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of MD as per item 2(b) of D.O.P, for the following 33 KV works:-

- (i) Laying of 150 mtrs. 33 KV S/C 3x300 SQmm. XLPE Cable + laying of 100 mtrs. 33 KV D/C 3x300 SQmm. XLPE U/G cable + erection of 800 mtrs. S/C O/H line on ACSR Dog Conductor from 132 KV GSS Kailadevi to existing 33 KV Karsai feeder at a distance of 5 KM from 33/11 KV S/S Karsai.


Note: 1) The 33/11 KV S/Ss Manch and Rattipura will remain on 33 KV Manch feeder emanating from 132 KV GSS Karauli whereas, 33/11 KV S/Ss Karsai and Maholi will remain on 33 KV Karsai feeder from 132 KV GSS Kailadevi.  
2) The above works are included in Annual Phase Programme 2018-19, under DDUGJY scheme.

  
(S.P. Gupta)

Superintending Engineer  
(Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The ACE (PPM), Jaipur Discom, Jaipur.
2. The Zonal Engineer (B/Z), Jaipur Discom, Bharatpur.
3. The Superintending Engineer (TW), Jaipur Discom, Jaipur.
4. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
5. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
6. The P.A. to SE (Plan), Jaipur Discom, Jaipur.

  
Superintending Engineer  
(Plan & Montg.) 30.4.18