

Email/Fax

PC no. 34

CIN: U40109RJ2000SGC016486

JAIPUR VIDYUT VITRAN NIGAM LIMITED
OFFICE OF THE SUPERINTENDING ENGINEER (PLAN & MONTG.)

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.
Telephone & Fax No. 0141-2747206, E-mail: seplan.jvvn@gmail.com

No. JPD/SE (Plan)/AEN(33KV works)/D. 624

Jaipur, Dated: 30/4/2018

The Superintending Engineer (JPDC),
Jaipur Discom,
Jaipur.

Sub:- Administrative approval for bifurcation of 33 KV Kishanpura feeder emanating from 132 KV GSS Govindgarh, Distt.- Jaipur (JPDC).

Ref: - ZCE (O&M-J/Z) office letter no. 116 dated 12.04.2018.

In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of MD as per item 2(b) of D.O.P, for the following 33 KV works:-

- (i) Erection of 7.56 KM. 33 KV S/C O/H line on ACSR Dog Conductor + laying of 200 mtrs. 33 KV D/C 3x300 SQmm. XLPE U/G cable + laying of 240 mtrs. 33 KV S/C 3x300 SQmm. XLPE U/G cable from 132 KV GSS Govindgarh to existing 33/11 KV S/S Heera Ka Bas.


- Note: 1) The 33/11 KV S/S Heera Ka Bas will shift on newly proposed 33 KV Heera Ka Bas feeder emanating from 132 KV GSS Govindgarh whereas, 33/11 KV S/Ss Kishanpura and Nangal govind will remain on 33 KV Kishanpura feeder from 132 KV GSS Govindgarh.
2) The above works are included in Annual Phase Programme 2018-19, under DDUGJY scheme.


(S.P. Gupta)

Superintending Engineer
(Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The ACE (PPM), Jaipur Discom, Jaipur.
2. The Zonal Engineer (J/Z), Jaipur Discom, Jaipur.
3. The Superintending Engineer (TW), Jaipur Discom, Jaipur.
4. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
5. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
6. The P.A. to SE (Plan), Jaipur Discom, Jaipur.


Superintending Engineer
(Plan & Montg.) 30.4.18