

Email/Fax

PC no. 04

CIN: U40109RJ2000SGC016486

## JAIPUR VIDYUT VITRAN NIGAM LIMITED

### OFFICE OF THE SUPERINTENDING ENGINEER (PLAN & MONTG.)

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.

Telephone & Fax No. 0141-2747206, E-mail: seplan.jvvn@gmail.com

No. JPD/SE (Plan)/AEN(33KV works)/D. 507

Jaipur, Dated: 4/4/18

The Superintending Engineer (O&M),  
Jaipur Discom,  
Alwar.


Sub:- Administrative approval for bifurcation of 33 KV Prithvipura feeder emanating from 132 KV GSS Malakhera, under AEN (O&M), JPD, Malakhera, Distt. - Alwar.

Ref: - 1) Your office note sheet no.11579 dated 07.03.2018.

In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of MD as per item 2(b) of D.O.P, for the following 33 KV works.

- (i) Erection of 3.25 KM 33 KV S/C O/H line on ACSR Dog Conductor T-off from 33 KV Beejwad feeder at a distance of 4 Km from 132 KV GSS Malakhera.

Note 1: The above works will be carried out under DDUGJY scheme in APP 2018-19




(S.P. Gupta)

Superintending Engineer  
(Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The Zonal Chief Engineer (J/Z), Jaipur Discom, Jaipur.
2. The Superintending Engineer (TW), Jaipur Discom, Jaipur.
3. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
4. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
5. The P.A. to SE (Plan), Jaipur Discom, Jaipur.

 4.4.18  
Superintending Engineer  
(Plan & Montg.)