

Email/Fax

PC no. 05

CIN: U40109RJ2000SGC016486

JAIPUR VIDYUT VITRAN NIGAM LIMITED
OFFICE OF THE SUPERINTENDING ENGINEER (PLAN & MONTG.)

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.

Telephone & Fax No. 0141-2747206, E-mail:seplan.jvvn@gmail.com

No. JPD/SE (Plan)/AEN(33KV works)/D. 508 Jaipur, Dated: 4/4/18

The Superintending Engineer (O&M),
Jaipur Discom,
Alwar.

Sub:- Administrative approval for bifurcation of 33 KV Machari feeder emanating from 132 KV GSS Rajgarh, under AEN (O&M), JPD, Rajgarh, Distt.- Alwar.

Ref: - 1) Your office note sheet no.11580 dated 07.03.2018.

In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of MD as per item 2(b) of D.O.P, for the following 33 KV works.


- (i) Erection of 4.75 KM 33 KV S/C O/H line on ACSR Dog Conductor T-off from 33 KV Machari feeder at a distance of 5.62 Km from 33/11 KV S/S Buchpuri to 33/11 KV S/S Lapala.

Note 1: The above works will be carried out under DDUGJY scheme in APP 2018-19


(S.P. Gupta)
Superintending Engineer
(Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The Zonal Chief Engineer (J/Z), Jaipur Discom, Jaipur.
2. The Superintending Engineer (TW), Jaipur Discom, Jaipur.
3. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
4. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
5. The P.A. to SE (Plan), Jaipur Discom, Jaipur.


Superintending Engineer
(Plan & Montg.)