

Email/Fax

PC no. 132

CIN: U40109RJ2000SGC016486

JAIPUR VIDYUT VITRAN NIGAM LIMITED
OFFICE OF THE SUPERINTENDING ENGINEER (PLAN & MONTG.)

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.
Telephone & Fax No. 0141-2747206, E-mail:seplan.jvvn@gmail.com

No. JPD/SE (Plan & Montg.)/AEN (33KV works)/D. 1986 Jaipur, Dated: 25/2/2019

The Superintending Engineer (O&M),
Jaipur Discom,
Karauli.


Sub:- Ex-post facto administrative approval for shifting of 33 KV line to 33/11 KV S/S Loharra supply from 132 KV GSS Kailadevi, Distt.- Karauli.

विषय— 132 के.वी. जी.एस.एस. कैलादेवी से 33/11 के.वी. सब-स्टेशन लोहार तक खींची जाने वाली 33 के.वी. लाईन में परिवर्तन हेतु पूर्वव्यापी प्रशासनिक स्वीकृति, जिला- करौली।

Ref: - 1) Your office letter no. 3428 dated 31.01.2019.

In consideration of the proposal furnished vide letter under reference, I am directed to convey the ex-post facto approval of MD as per item 2(b) of D.O.P, for the following 33 KV works.

- (i) Laying of 0.175 KM 33 KV 3x300 SQmm. XLPE D/C by U/G cable from 132 KV GSS Kailadevi.
- (ii) Erection of 1.325 KM 33 KV S/C O/H line on ACSR Dog Conductor (for new route) from 0.175 KM D/C U/G cable to already existing 33 KV Loharra feeder at a distance of 5.5 KM from 33/11 KV S/S Loharra.



(M.L. Gupta)
Superintending Engineer
(Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The ACE (PPM), Jaipur Discom, Jaipur.
2. The Zonal Engineer (B/Z), Jaipur Discom, Bharatpur.
3. The Superintending Engineer (TW), Jaipur Discom, Jaipur.
4. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
5. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
6. The P.A. to SE (Plan), Jaipur Discom, Jaipur.


25/2/19
Superintending Engineer
(Plan & Montg.)