

PC no..17

CIN: U40109RJ2000SGC016486

JAIPUR VIDYUT VITRAN NIGAM LIMITED
OFFICE OF THE SUPERINTENDING ENGINEER
(PLAN & MONTG.)

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.
Telephone & Fax No. 0141-2747206, E-mail:seplan@jvvn.org

No. JPD/SE(Plan & Montg.)/ XEN(Plan)/AEN(33KV works)/D. 684 Jaipur, Dated: 13/9/2019

The Superintending Engineer (JCC),
Jaipur Discom,
Jaipur.

Sub:- Administrative approval for providing alternate source of 33 KV supply for 33/11 KV S/S Jal Mahal by laying of 0.950 Km 33 KV 3x300 Sq.mm. XLPE U/G cable, Distt. Jaipur (JCC).

विषय:- 33/11 के.वी. सब- स्टेशन जल महल, जिला- जयपुर (जयपुर शहर वृत्त) को 0.95 किलोमीटर 33 के. वी. अंडरग्राउंड केबल खींचकर विद्युत आपूर्ति का वैकल्पिक स्रोत प्रदान करने के कार्य की प्रशासनिक स्वीकृति हेतु।


Ref: - SE(JCC), Jaipur office letter no. 2879 dated 05.08.2019.

In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of MD as per item 2(b) of D.O.P, for the following 33 KV works:-

- (i) Laying of 0.950 KM 33 KV S/C 3x300 Sq.mm. XLPE U/G cable T-off from 33 KV Nahri Ka Naka feeder emanating from 220 KV GSS NPH at a distance of 1.5 Kms (at Ramgarh Mod) from 33/11 KV S/S Brahmपुरी to 33/11 KV S/S Jal Mahal as an alternate source of supply.


Note:-

1. The above works are subject to budget availability as per JPD/rules-1235 letter no. 4181 dated 29.01.2019.


(M.L. Gupta)
Superintending Engineer
(Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The ACE (PPM), Jaipur Discom, Jaipur.
2. The Zonal Engineer (J/Z), Jaipur Discom, Jaipur.
3. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
4. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
5. The P.A. to SE (Plan), Jaipur Discom, Jaipur.


Superintending Engineer
(Plan & Montg.)