

JAIPUR VIDYUT VITRAN NIGAM LIMITED
OFFICE OF THE SUPERINTENDING ENGINEER
(PLAN & MONTG.)

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.
 Telephone & Fax No. 0141-2747206, E-mail:seplan@jvvn.org

No. JPD/SE (Plan & Montg.)/AEN(33KV works)/D. 196 Jaipur, Dated: 28/5/2019

The Superintending Engineer (O&M),
 Jaipur Discom,
 Baran.

Sub:- Administrative approval for 33 KV interconnection of 33/11 KV S/S Kalmanda to 33 KV Mandoli feeder from 132 KV GSS Baran and revised administrative approval for 33 KV I/C of 33/11 KV S/S Amapura from 220 KV GSS Baran, Distt.-Baran.

विषय:- 33/11 के.वी. सब-स्टेशन कल्मण्डा से 33 के.वी. मंडोली फीडर (जो 132-के.वी. ग्रिड सब-स्टेशन बारों से निकल रहा है) तक 33 के.वी. लाइन खींचने के निर्माण कार्य की प्रशासनिक स्वीकृति हेतु एवं 33/11 के.वी. सब-स्टेशन अमापुरा से 220 के.वी. ग्रिड सब-स्टेशन बारों तक 33 के.वी. लाइन्स खींचने के निर्माण कार्य की प्रशासनिक स्वीकृति पुनः जारी करने हेतु, जिला- बारों।


Ref: - TA to ZCE(O&M-JZ) office letter no. 3854 dated 12.03.2019.

In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of MD as per item 2(b) of D.O.P, for the following 33 KV works:-

- (i) Creation of 1x5.0 MVA, 33/11 KV S/S at Amapura, Distt. Baran with 04 no. 11 KV outgoing feeder.
- (ii) Erection of 1.50 KM 33 KV S/C O/H line on ACSR Dog conductor from 33/11 KV S/S Kalmanda to 33/11 KV S/S Mandoli.
- (iii) Erection of 1.78 KM 33 KV S/C O/H line on ACSR Dog conductor from 33 KV Kalmanda feeder from 220 KV GSS Baran at a distance of 8.5 KM to 33/11 KV S/S Amapura.
- (iv) Laying of 0.06 KM 33 KV D/C U/G cable at Baran Jhalawar road crossing (twice).

Note:-


- i) After execution of proposed bifurcation work, proposed 33 KV Mandoli/feeder no.9 feeder will cater the load of 33/11 KV S/S Mandoli & Kalmanda. The remaining 33 KV Kalmanda feeder will cater the load of 33/11 KV S/S Amapura and M/s Shiv Agro ltd.
- ii) The previous administrative approval of 33/11 KV S/S Amapura issued vide this office letter no. 900 (PC no. - 69) dated 18.06.2018 is hereby withdrawn.
- iii) The above works were included under IPDS scheme in APP 2018-19.
- iv) The above works are subject to budget availability as per JPD/rules-1235 letter no. 4181 dated 29.01.2019.


 (M.L. Gupta)
 Superintending Engineer
 (Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The ACE (PPM), Jaipur Discom, Jaipur.

2. The Zonal Engineer (K/Z), Jaipur Discom, Kota.
3. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
4. The Superintending Engineer (TW), Jaipur Discom, Jaipur.
5. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
6. The P.A. to SE (Plan), Jaipur Discom, Jaipur.


28/5/18
Superintending Engineer
(Plan & Montg.)