

**JAIPUR VIDYUT VITRAN NIGAM LIMITED**  
**OFFICE OF THE SUPERINTENDING ENGINEER**  
**(PLAN & MONTG.)**

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.  
Telephone & Fax No. 0141-2747206, E-mail:seplan@jvvn.org

No. JPD/SE(Plan & Montg.)/ XEN(Plan)/AEN(33KV works)/D. 844 Jaipur, Dated: 21/10/19

The Superintending Engineer (O&M),  
Jaipur Discom,  
Alwar.

**Sub:- Administrative approval for bifurcation of 33 KV Sotanala feeder from 132 KV GSS Keshwana, Distt. Alwar.**

विषय:- 33 के.वी. सोटानाला फीडर (जो 132 के.वी. ग्रिड सब-स्टेशन केशवाना से निकल रहा है) के विभाजन कार्य की प्रशासनिक स्वीकृति हेतु, जिला- अलवर।


Ref: - SE(O&M), Alwar office letter no. 2651 dated 18.09.2019.

In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of MD as per item 2(b) of D.O.P, for the following 33 KV works:-

- (i) Laying of 0.3 KMs 33 KV S/C U/G 3x300 Sq.mm. XLPE cable (Main GSS Exit) plus laying of 0.13 KMs 33 KV D/C U/G 3x300 Sq.mm. XLPE cable (at NH-8 crossing) plus erection of 5.15 KM 33 KV S/C O/H line on ACSR Dog conductor from 132 KV GSS Keshwana to 33/11 KV S/S Sotanala.


Note:-

1. The above works are subject to budget availability as per JPD/rules-1235 letter no. 4181 dated 29.01.2019.

  
(M.L. Gupta)  
Superintending Engineer  
(Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The ACE (PPM), Jaipur Discom, Jaipur.
2. The Zonal Engineer (J/Z), Jaipur Discom, Jaipur.
3. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
4. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
5. The P.A. to SE (Plan), Jaipur Discom, Jaipur.

  
Superintending Engineer  
(Plan & Montg.)