

**JAIPUR VIDYUT VITRAN NIGAM LIMITED**  
**OFFICE OF THE SUPERINTENDING ENGINEER**  
**(PLAN & MONTG.)**

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.  
Telephone & Fax No. 0141-2747206, E-mail:seplan@jvvn.org

No. JPD/SE (Plan & Montg.)/AEN(33KV works)/D. 197 Jaipur, Dated: 28/5/2019

The Superintending Engineer (O&M),  
Jaipur Discom,  
Jhalawar.

**Sub:- Administrative approval for 33 KV interconnection from 220 KV GSS  
Kotra Jagir to 33/11 KV S/S Ghatoli, Distt. Jhalawar.**

विषय:- 220 के.वी. ग्रिड सब-स्टेशन कोटरा जागीर से 33/11 के.वी. सब-स्टेशन घाटोली तक 33 के.वी. लाइन खींचने के निर्माण कार्य की प्रशासनिक स्वीकृति हेतु, जिला-झालावाड़।


Ref: - Your office letter no. 7064 dated 15.03.2019.

In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of MD as per item 2(b) of D.O.P, for the following 33 KV works:-

- (i) Erection of 8.5 KMs 33 KV S/C O/H line on ACSR Dog conductor from 220 KV GSS Kota Jagir to 33/11 KV S/S Ghatoli.


Note:-

- (i) After the proposed interconnection, new proposed 33 KV Ghatoli feeder from 220 KV GSS Kotra Jagir will supply 33/11 KV S/S Ghatoli & Sarda and remaining 33 KV Bhatla feeder from 132 KV GSS Aklera will supply 33/11 KV S/S Bhatla.  
(ii) The above works are included under ST Plan.  
(iii) The above works are subject to budget availability as per letter no. JPD/rules-1235 D. 4181 dated 29.01.2019.

  
(M.L. Gupta) 28/5/19.  
Superintending Engineer  
(Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The ACE (PPM), Jaipur Discom, Jaipur.
2. The Zonal Engineer (K/Z), Jaipur Discom, Kota.
3. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
4. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
5. The P.A. to SE (Plan), Jaipur Discom, Jaipur.

  
28/5/19  
Superintending Engineer  
(Plan & Montg.)