

Email/Fax

PC no. 3..

CIN: U40109RJ2000SGC016486

JAIPUR VIDYUT VITRAN NIGAM LIMITED

OFFICE OF THE SUPERINTENDING ENGINEER

(PLAN & MONTG.)

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.

Telephone & Fax No. 0141-2747206, E-mail:seplan@jvvn.org

No. JPD/SE (Plan & Montg.)/AEN(33KV works)/D. 198

Jaipur, Dated: 28/5/2019

The Superintending Engineer (JCC),
Jaipur Discom,
Jaipur.

Sub:- Administrative approval for providing alternate source of 33/11 KV S/S Meera Marg by laying of 6.60 KM 33 KV 3x300 Sq.mm. XLPE U/G cable from 220 KV GSS Madrampura, Distt. Jaipur (JCC).

विषय:- 33/11 के.वी. सब-स्टेशन मीरा मार्ग, जिला- जयपुर (जयपुर शहर वृत्त) को 6.60 किलोमीटर 33 केवी अंडरग्राउंड केबल खींचकर विद्युत आपूर्ति का वैकल्पिक स्रोत प्रदान करने के कार्य की प्रशासनिक स्वीकृति हेतु।

Ref: - TA to ZCE(O&M-JZ) office letter no. 3854 dated 12.03.2019.

In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of MD as per item 2(b) of D.O.P, for the following 33 KV works:-

- (i) Laying of 6.6 KMs 33 KV S/C 3x300 Sq.mm. XLPE U/G cable from 220 KV GSS Madrampura to 33 KV Sanganer feeder at a distance of 1.0 KM from 33/11 KV S/S Meera Marg.

Note:-


1. The above works are included under ST Plan.
2. The above works are subject to budget availability as per JPD/rules-1235 letter no. 4181 dated 29.01.2019.


28/5/19
(M.L. Gupta)

Superintending Engineer
(Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The Zonal Engineer (J/Z), Jaipur Discom, Jaipur.
2. The ACE (PPM), Jaipur Discom, Jaipur.
3. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
4. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
5. The P.A. to SE (Plan), Jaipur Discom, Jaipur.


28/5/19
Superintending Engineer
(Plan & Montg.)