

JAIPUR VIDYUT VITRAN NIGAM LIMITED
OFFICE OF THE SUPERINTENDING ENGINEER
(PLAN & MONTG.)

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.
 Telephone & Fax No. 0141-2747206, E-mail:seplan@jvvn.org

No. JPD/SE(Plan & Montg.)/ XEN(Plan)/AEN(33KV works)/D. 374 Jaipur, Dated: 8/7/2019

The Superintending Engineer (O&M),
 Jaipur Discom,
 Kota.

Sub:- Administrative approval for additional 33 KV Bay at 132 KV GSS Itawa and laying of 33 KV U/G cable in order to cater the load of 33/11 KV S/S Genta on a separate feeder, Distt.- Kota.

विषय:- 132 के.वी. ग्रिड सब-स्टेशन इटावा पर 33/11 के. वी. सब-स्टेशन गेंता को एक अलग फीडर से विद्युत आपूर्ति देने के लिए अतिरिक्त 33 के.वी. बे एवं 33 के. वी. अंडरग्राउंड केबल डालने की प्रशासनिक स्वीकृति हेतु, जिला- कोटा।


Ref: - Your office letter no. 657 dated 10.05.2019.

In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of MD as per item 2(b) of D.O.P, for the following 33 KV works:-

- i) Erection of 30 mtrs 33 KV S/C O/H line from new proposed 33 KV Bay at 132 KV GSS Itawa to a proposed tower.
- ii) Laying of 130 mtrs 33 KV D/C 3x300 Sq.mm. XLPE U/G cable from proposed tower to 33 KV Chambal Deepri feeder.

Note:-

1. The above works are included under ST Plan.
2. The above works are subject to budget availability as per JPD/rules-1235 letter no. 4181 dated 29.01.2019.
3. The cost of additional 33 KV Bay will be deposited to RRVPNL.


 Superintending Engineer
 (Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The Zonal Engineer (K/Z), Jaipur Discom, Kota.
2. The ACE (PPM), Jaipur Discom, Jaipur.
3. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
4. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
5. The P.A. to SE (Plan), Jaipur Discom, Jaipur.


 Superintending Engineer
 (Plan & Montg.)