

**JAIPUR VIDYUT VITRAN NIGAM LIMITED**  
**OFFICE OF THE SUPERINTENDING ENGINEER**  
**(PLAN & MONTG.)**Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.  
Telephone & Fax No. 0141-2747206, E-mail:seplan@jvvn.org

No. JPD/SE(Plan &amp; Montg.)/ XEN(Plan)/AEN(33KV works)/D. 700 Jaipur, Dated: 18/9/2019

The Superintending Engineer (JCC),  
Jaipur Discom,  
Jaipur.**Sub:- Administrative approval for laying 850 mtrs 33 KV 3x300 Sq.mm. XLPE U/G cable from 132 KV GSS Dak Bunglow to 33/11 KV S/S Chandpole as a second source, Distt. Jaipur (JCC).**

विषय:- 132 के.वी. गिड सब- स्टेशन डाक बंगला से 33/11 के.वी. सब- स्टेशन चाँदपोल, जिला- जयपुर (जयपुर शहर वृत्त) तक 850 मीटर 33 के. वी. अंडरग्राउंड केबल खींचकर विद्युत आपूर्ति का वैकल्पिक स्रोत प्रदान करने के कार्य की प्रशासनिक स्वीकृति हेतु।


Ref: - SE(JCC), Jaipur office letter no. 1379 dated 09.07.2019.

In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of MD as per item 2(b) of D.O.P, for the following 33 KV works:-

- (i) Laying of 0.85 KMs 33 KV 3x300 Sq.mm. XLPE S/C U/G cable from 132 KV S/S Dak Bunglow to 33/11 KV S/S Chandpole.


Note:-

1. The above works are included under ST Plan.
2. The above works are subject to budget availability as per JPD/rules-1235 letter no. 4181 dated 29.01.2019.

  
(M.L. Gupta)  
Superintending Engineer  
(Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The ACE (PPM), Jaipur Discom, Jaipur.
2. The Zonal Engineer (J/Z), Jaipur Discom, Jaipur.
3. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
4. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
5. The P.A. to SE (Plan), Jaipur Discom, Jaipur.

  
Superintending Engineer  
(Plan & Montg.)