

JAIPUR VIDYUT VITRAN NIGAM LIMITED
OFFICE OF THE SUPERINTENDING ENGINEER
(PLAN & MONTG.)

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.
Telephone & Fax No. 0141-2747206, E-mail:seplan@jvvn.org

No. JPD/SE(Plan & Montg.)/ XEN(Plan)/AEN(33KV works)/D. 770 Jaipur, Dated: 03/10/2019

The Superintending Engineer (JPDC),
Jaipur Discom,
Jaipur.

Sub:- Administrative approval for bifurcation of 33 KV Kadedda feeder from 220 KV GSS Chaksu, Distt. Jaipur (JPDC).

विषय:- 33 के.वी. काडेडा फीडर (जो 220 के.वी. ग्रिड सब-स्टेशन चाकसू से निकल रहा है) के विभाजन कार्य की प्रशासनिक स्वीकृति हेतु, जिला- जयपुर (जयपुर जिला वृत्त)।


Ref: - SE(JPDC), Jaipur office letter no. 5997 dated 18.09.2019.

In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of MD as per item 2(b) of D.O.P, for the following 33 KV works:-

- (i) Laying of 0.12 KMs 33 KV 3x300 Sq.mm. XLPE S/C U/G cable from 220 KV GSS Chaksu to 33 KV Kadedda feeder at a distance of 18.0 KM from 33/11 KV S/S Kadedda.

Note:-

1. The above works are subject to budget availability as per JPD/rules-1235 letter no. 4181 dated 29.01.2019.


(M.L. Gupta)

Superintending Engineer
(Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The ACE (PPM), Jaipur Discom, Jaipur.
2. The Zonal Engineer (J/Z), Jaipur Discom, Jaipur.
3. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
4. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
5. The P.A. to SE (Plan), Jaipur Discom, Jaipur.


(M.L. Gupta)

Superintending Engineer
(Plan & Montg.)