

JAIPUR VIDYUT VITRAN NIGAM LIMITED
OFFICE OF THE SUPERINTENDING ENGINEER (PLAN & MONTG.)

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.
 Telephone & Fax No. 0141-2747206, E-mail: seplan.jvvn@gmail.com

No. JPD/SE(Plan & Montg.)/ XEN(Plan)/AEN(33KV works)/D. 901 Jaipur, Dated: 11/11/19

The Superintending Engineer (O&M),
 Jaipur Discom,
 Jhalawar.

Sub:- Revised administrative approval for erection of 33 KV line from 132 KV GSS Khanpur to 33/11 KV S/S Soomer, Distt.-Jhalawar.

विषय:- 132 के.वी. बिड सब-स्टेशन खानपुर से 33/11 के.वी. सब-स्टेशन सुमर तक 33 के.वी. लाइन खींचने की संशोधित प्रशासनिक स्वीकृति हेतु, जिला- झालावाड़ ।

Ref: - 1) Your office letter no.2956 dated 18.09.2019.

In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of MD as per item 2(b) of D.O.P, for the following 33 KV works:-

(i) Laying of 0.195 KM 33 KV D/C U/G 3x300 Sq.mm. XLPE cable from 132 KV GSS Khanpur to already erected 9.025 Km 33 KV S/C O/H line from 33/11 KV S/S Soomer.

Note:-

1. After execution of proposed work, proposed 33 KV Kanwarpura Mand feeder emanating from 132 KV GSS Khanpur will cater the load of 33/11 KV S/S Kanwarpura Mand & Jolpa and 33 KV Khanpur feeder emanating from 132 KV GSS Khanpur will cater the load of 33/11 KV S/Ss Khanpur, Soomer & Bhagwanpura.
2. The above works are subject to budget availability as per JPD/rules-1235 letter no. 4181 dated 29.01.2019.

(M.L. Gupta)

**Superintending Engineer
(Plan & Montg.)**

Copy submitted/forwarded to the following for information and necessary action:-

1. The ACE (PPM), Jaipur Discom, Jaipur.
2. The Zonal Engineer (K/Z), Jaipur Discom, Kota.
3. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
4. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
5. The P.A. to SE (Plan), Jaipur Discom, Jaipur.

**Superintending Engineer
(Plan & Montg.)**