

**JAIPUR VIDYUT VITRAN NIGAM LIMITED**  
**OFFICE OF THE SUPERINTENDING ENGINEER (PLAN & MONTG.)**

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.  
Telephone & Fax No. 0141-2747206, E-mail: seplan@jvvn.org

No. JPD/SE(Plan & Montg.)/XEN(Plan)/AEN(33KV works)/D. 915 Jaipur, Dated: 13/11/19

The Superintending Engineer (JCC),  
Jaipur Discom,  
Jaipur.

**Sub:- Administrative approval for providing 33 KV Sectionalizing switch between 33 KV Goner feeder emanating from 132 KV GSS Purana Ghat and 33 KV MREC/Luniyawas feeder emanating from 132 KV GSS Purana Ghat by laying of 165 mtrs. 3x300 Sq.mm. XLPE U/G cable at near boundary of 33/11 KV S/S Luniyawas, Distt.-Jaipur (JCC).**

विषय- 33 के.वी. गोनर फीडर (जो कि 132 के.वी. ग्रिड सब-स्टेशन पुराना घाट से निकल रहा है) एवं 33 के.वी. एमआरईसी/ लुनियावास फीडर (जो कि 132 के.वी. ग्रिड सब-स्टेशन पुराना घाट से निकल रहा है) के बीच सेक्शनलाइज़र स्विच लगाने एवं 165 मीटर 33 के. वी. XLPE अंडरग्राउंड केबल 33/11 के.वी. सब-स्टेशन लूनीयावास की बाउंडरी के पास खींचने की प्रशासनिक स्वीकृति हेतु, जिला-जयपुर(जयपुर शहर वृत्त) ।

Ref: - 1) Your office letter no.3097 dated 20.08.2019.

In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of MD as per item 2(b) of D.O.P, for the following 33 KV works:-

- Construction of 33 KV sectionalizing switch with 02 nos G.O. on 33 KV Goner feeder emanating from 132 KV GSS Purana Ghat after 33/11 KV S/S Luniyawas.
- Laying of 45 mtrs 33 KV S/C 3x300 Sq.mm. XLPE U/G cable from existing 33 KV Goner/Purana Ghat incoming feeder to proposed G.O. in sectionalizing switch.
- Laying of 40 mtrs 33 KV S/C 3x300 Sq.mm. XLPE U/G cable from proposed G.O. in sectionalizing switch to 33 KV 33 KV Goner outgoing feeder on 33/11 KV S/S Luniyawas.
- Laying of 45 mtrs 33 KV S/C 3x300 Sq.mm. XLPE U/G cable from proposed G.O. in sectionalizing switch to 33 KV Isolator in 33 KV Goner/Purana Ghat incoming feeder.
- Laying of 35 mtrs 33 KV S/C 3x300 Sq.mm. XLPE U/G cable from 33/11 KV S/S Luniyawas to already laid 5.618 KMs 33 KV MREC feeder from 132 KV GSS Purana Ghat.

Note:- The above works are subject to budget availability as per JPD/rules-1235 letter no. 4181 dated 29.01.2019.

*(M.L. Gupta)*  
13.11.19

(M.L. Gupta)  
Superintending Engineer  
(Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

- The ACE (PPM), Jaipur Discom, Jaipur.
- The Zonal Engineer (J/Z), Jaipur Discom, Jaipur.
- The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
- The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
- The P.A. to SE (Plan), Jaipur Discom, Jaipur.

*(M.L. Gupta)*  
13.11.19  
Superintending Engineer  
(Plan & Montg.)