

JAIPUR VIDYUT VITRAN NIGAM LIMITED
OFFICE OF THE SUPERINTENDING ENGINEER
(PLAN & MONTG.)

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.
Telephone & Fax No. 0141-2747206, E-mail:seplan@jvvn.org

No. JPD/SE(Plan & Montg.)/ XEN(Plan)/AEN(33KV works)/D.538

Jaipur, Dated: 13/8/2019

The Superintending Engineer (O&M),
Jaipur Discom,
Dholpur.

Sub:- Revised administrative approval for erection of 7.0 KMs 33 KV line in place of 14.0 KMs 33 KV line for 33/11 KV S/S Moroli, Distt.- Dholpur.


विषय:- 33/11 के.वी. सब-स्टेशन मोरोली के लिए पूर्व में स्वीकृत 14.0 कि.मी. 33 के.वी. लाईन के स्थान पर 7.0 कि.मी. 33 के.वी. लाईन खींचने हेतु संशोधित स्वीकृति, जिला - धौलपुर।

Ref: - Your office letter no. 2691 dated 19.07.2019.

In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of MD as per item 2(b) of D.O.P, for the following 33 KV works:-


- (i) Erection of 7.0 KMs 33 KV S/C O/H line on ACSR Dog Conductor T-off from 33 KV Basai Dang feeder emanating from 220 KV GSS Dholpur at a distance of 15.0 KMs from 220 KV GSS Dholpur to proposed 33/11 KV S/S Moroli.

Note:- The previous administrative approval of erection of 14.0 KMs S/C line from 33/11 KV S/S GTR to 33/11 KV S/S Moroli issued vide this office letter no. 3081 (PC no. - 119) dated 10.12.2010 is hereby withdrawn.


13.8.19
Superintending Engineer
(Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The ACE (PPM), Jaipur Discom, Jaipur.
2. The Zonal Engineer (B/Z), Jaipur Discom, Bharatpur.
3. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
4. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
5. The P.A. to SE (Plan), Jaipur Discom, Jaipur.


13.8.19
Superintending Engineer
(Plan & Montg.)