

**JAIPUR VIDYUT VITARAN NIGAM LIMITED  
OFFICE OF THE SUPERINTENDING ENGINEER (PROC)  
OLD POWER HOUSE PREMISES, NEAR RAM  
MANDIR, BANIPARK, JAIPUR-6**

**FAX:0141- 2208098, TELE:0141- 2208098**

**SPECIFICATION FOR SUPPLY OF DANGER PLATES  
AGAINST BID NOTICE NO. JPD/SE(Proc)/SPO.III/TN-4585**

<b>Last Date of receipt of bids</b>	<b>19.12.2016 upto 2:30 PM</b>
<b>Date of opening of bids</b>	<b>20.12.2016 at 3:00 PM</b>
<b>Cost of Specification</b>	<b>Rs.2500.00 ( Rs. Two Thousand Five Hundred only)</b>
<b>Validity</b>	<b>120 days from the next date of opening of tenders.</b>
<b>Earnest Money</b>	<b>Rs. 50,000.00 (Rs. Fifty Thousand only) / Exemption Certificate / Vendor Registration Of Class "E" Category or above.</b>

**Note : The bidders in their own interest are advised to go through the complete specification carefully.**

## **INDEX**

Section-I	Instructions to bidders	
Section-II	General Conditions of Contract	
Section-III	Technical Specification	
Schedule-I	Schedule of Requirement	
Schedule-III	Details of Standards	
Schedule-IV	Price Schedule	To be submitted in Price Bid Envelop.
Schedule V	Departure from Guaranteed Technical Particulars	
Schedule V A	Guaranteed Technical Particulars	
Schedule VI A	Departure from the requirement of Technical Specification.	
Schedule VI B	Departure from commercial terms & conditions of specification	
Schedule VII	List of Past supplies.	
Schedule VIII	Delivery schedule.	
Schedule IX	List of equipment & technical hands available with the bidding firm.	
Schedule X	General Particulars about the bid in brief.	

**Note:- The bidder, in their own interest, are requested to read very carefully Section-I (Instruction to bidders), Section-II (General Condition of Contract) & Section-III (Technical Specification) before filling the bid. The Bid documents be downloaded from JVVNL website [www.jaipurdiscom.in](http://www.jaipurdiscom.in) . No hard copy of the bidding documents will be provided to the bidders through this office. In case of any discrepancy found in bidding documents downloaded from the website and appended with the bid (as a bid document) and original copy of such document available in the office of Superintending Engineer (Proc.), Jaipur Discom, Jaipur then the copy available with Superintending Engineer (Proc.), Jaipur Discom, Jaipur will be considered as final document for all purpose. The cost of Bid document as published in NIT shall be furnished along with downloaded bid document in the manner prescribed in bid document.**

**Section-III****TECHNICAL SPECIFICATION FOR THE SUPPLY OF DANGER LABEL/ PLATES FOR 33/11 KV & 11/0.4 KV SUB-STATIONS AGAINST TN-4585.****3.01 SCOPE**

This specification covers the fabrication, manufacture, testing, checking & supply of Danger Label/ plates for 33/11KV & 11/0.4 KV Sub-Stations. Before despatch of material, the inspection testing & checking will be witnessed by the representative of the purchaser.

**3.02 SPECIFICATIONS & STANDARDS:**

The relevant ISS to which this material shall conform are indicated as below:-

S.NO.	Bureau of Indian Standards	Title
a)	IS:2551-1982 ( Latest amended)	For general checking
b)	IS-5-1978 ( Latest amended)	For colours for ready mixed paints an enamels.
c) i.	IS:3972 (Pt.2/Sec.1):1985	For resistance to citric acid at room temperature and boiling temperature.
ii)	IS:3972 (Pt.2/Sec.1)1985	For low & high voltage tests for detecting and locating defects.
iii)	IS:3972 (Pt.1)Sec.1):1982	For production of Specimen for testing.

**3.03 DIMENSIONS:-**

S. No.	Items	Nominal thickness of M.S. Plate (Min.)	Other dimension as per ISS	
			Length in mm	Width in mm.
1.	Danger Plates for 33/11 KV & 11/0.4 KV Sub-stations.	1.6mm	250	200
			IS-2551/1982 (latest amended)	

### **3.04 GUARANTEED TECHNICAL & OTHER PARTICULARS.**

The GTP of Danger Label/ plate should be given in the tender technical particulars and other particulars of material in Schedule-V.

#### **3.04.1 Material**

The Danger plates shall be made from mild steel sheet of at least 1.6mm thick and vitreous enamelled white with letters, figures and conventional skull and cross bones in signal red colour conforming to IS-5-1978 on the front side and rear side should be enameled black. The edges & rear side should be enamelled black. Holders for fixing the plates should be drilled not punched.

**3.06 Prices:** Prices offered against the specification shall be **FIRM**.

### **3.07 DELIVERY SCHEDULE**

The bidder is required to quote monthly delivery. The delivery of quoted quantity should be completed in **Five months** period including commencement period of **maximum 30 days**. In case ordered quantity is different than quoted quantity then monthly delivery shall be adjusted proportionately. Tenders in which monthly delivery schedule is not indicated shall be ignored.

### **3.08 TESTS:-**

In order to ensure that Danger plates conform to the specification the following tests are to be carried out:-

- a) Visual Examination.
- b) Dimensional check including checking of thickness of M.S. Plate and weight.
- c) Test for weather proofness.
- d) Checking of thickness of enamel.
- e) Resistance to citric acid at room temperature.
- f) Low & high voltage tests for detecting and locating defects.

### **3.09 INSPECTION:-**

The number of samples of danger plates selected at random from the lot shall be in accordance with the table given below:-

Lot size	First sample for tests a,b,c, d,e & f.	sample size for checking of thickness of steel plate & enamelling.	Permissible Rejection number.	Second sampling.	Permissible Rejection number
a)	Upto 500	5	1	0	2
b)	501 to 800	7	2	0	3
c)	801 to 1300	10	4	0	3
d)	1301 to 3200	15	6	1	4
e)	3201 to 8000	25	8	2	5
f)	8001 & above	35	10	2	7

The checking of the thickness of M.S. Plates and enamelling on the plates number of samples as per Column 3 is acceptable provided the rejection of the samples is not more than the number mentioned in column 4.

In the event of rejection being more than the number in Column 4 double the sampling as per Column 5 be done. Incase of rejection of samples is beyond the number mentioned at 6, the lot shall be considered rejected.

On inspection/ testing/checking, if the material is found acceptable as per above criteria the purchaser's representative shall seal the material, before despatch.

### 3.10 MARKING

The essential information that would be necessary to identify the manufacture of Danger Plates such as JVNL, Purchase Order No. & Date shall be marked in such a manner & position on the plates that it does not interfere with the other information and should be of permanent nature.

### 3.11 DRAWING

The dimensions of Danger plate shall be confirm to the following drawings & our specification (copy enclosed)

Drawing for	Drawing No.
33/11 KV S/S	SE(Proc)/SPO-III/TN-4585/01
11/0.4 KV S/S	SE(Proc)/SPO-III/TN-4585/02

### **3.12 TEST CHECKING OF MATERIAL AT TESTING LABORATORY:**

The material received in stores of nigam shall be subjected to the test checking at testing laboratory before final acceptance of material. The procedure for testing shall be as under:

#### **i) SAMPLING**

One sample out of each sub lot/ lot of (1000 Nos.) thousand Nos. or part thereof from each inspected lot received in stores shall be selected from each store for test checking of material and shall be got tested. The selection of sample from the material received at stores shall be done as soon as material is received in stores without the presence of the representative of the supplier. However, testing of sample(s) at CTL or else where as arranged by the JVVNL shall be carried out in the presence of representative of the supplier after identification / confirmation by him that samples so selected belong to them.

#### **ii) TESTS**

The following test shall be carried out on the above samples :

- a) Visual examination, verification of dimensions, weight and marking as per GTP/ISS/Specification/ approved drawing.

For witnessing of the testing, clear 7 (seven) days notice shall be given to the supplier by fax/ speed post stating date, time & place where the test is to be conducted. In case the supplier do not attend for witnessing the testing, the testing shall be proceeded and completed and action be taken as per the contract.

The Officer Incharge of Central Testing Lab (CTL) Jaipur shall send copies of test reports to the purchaser, consignees and the supplier.

#### **iii) CRITERIA FOR ACCEPTANCE**

- a) Visual Examination, verification of dimensions, weight and marking.

As per Specification/ GTP/ ISS/approved drawing.

#### **iv) TEST CHARGES :**

All test charges incurred towards test checking of the material received in our stores shall be borne by the NIGAM except that of personal expenses of the representative of the supplier for witnessing the tests.

**v) PAYMENT:**

Payment shall be made only after receipt of successful test report from the CTL on the samples selected from the material received at the stores. However, the due dates for payment shall be considered from the date of submission of the bills along with receipted challans to Accounts Officer (CPC), JVVNL, Jaipur.

**3.13 PACKING**

You shall pack the material in the suitable wooden cases so that the material may not be damaged in the transit and also remain protected from the atmosphere.

**3.14 DEPARTURE FROM SPECIFICATION**

Should the tenderer depart from the specification in any respect, he should clearly state such departures indicating the reasons thereof. Unless this is done, the departmental specification will hold good and shall be binding on the supplier unless the departures have been approved in writing by the purchaser.

**3.15 TENDERS:**

Tenderer shall furnish complete particulars of the material offered by them in regard to the specification and submit the same with their tender. Failure to do so or any incomplete entry therein may prevent a tender from being considered.

The tenders received without complete details required as per enclosed forms/ schedules are liable to be rejected.

**3.17 Quantity tolerance:** Quantity tolerance of plus minus 2% of ordered quantity shall be allowed for completion of supply

**SCHEDULE-I****SCHEDULE OF REQUIREMENT**

S.No.	Particulars	Qty in Nos
1	Danger Plates	32856

The requirement of Danger Plates as indicated above is tentative and can be increased or decreased at the time of placing of the order.



## Schedule – III



**JAIPUR VIDYUT VITRAN NIGAM LIMITED**

**A Govt. of Rajasthan Undertaking  
Prescribed technical specification for supply of  
(Name of Material/Equipment/Machinery/T&P etc.)**

**DANGER PLATE**

S.No.	Technical specification particulars standard specification Machinery/T&P shall conform	Name of IS/other to which material/equipment/ if any. to which material should	Other
	conform		
1.	For general checking	IS:2551-1982 (Latest amended)	
2.	For colours for ready mixed Paints an enamels.	IS-5- 1978 (Latest amended)	
3.i)	For resistance to citric acid at Room temperature and boiling Temperature.	IS:3972 (Pt.2/Sec.1):1985	
ii)	For low & high voltage tests for detecting and locating defectes.	IS:3972 (Pt.2/Sec.1):1985	
iii)	For production of specimen for testing	IS:3972 (Pt.2/Sec.1):1982	

Certified that we agree to all the aforesaid technical specification except at S.No..... for which our technical specification shall be as under:-

S.No.	Technical specification particulars standard specification Machinery/T&P shall confirm	Name of IS/other to which material/equipment/ if any. to which material should	Other confirm

**(Signature)**  
Name & Designation  
with seal of the bidder.



## Schedule – IV

### JAIPUR VIDYUT VITRAN NIGAM LIMITED

#### A Govt. of Rajasthan Undertaking SCHEDULE OF PRICES

(Must be filled by the bidder and returned with the bid)

The Superintending Engineer (Proc. /MM)

\_\_\_\_\_ Vidyut Vitran Nigam Limited \_\_\_\_\_

with reference to your invitation to bid against specification No....., we agree to supply at prices (firm/variable) given as follows

S. No.	Particulars of Material	Quantity offered	Unit Ex-works Price (in Rs.)	Excise duty (Per Unit)		Cess on Excise Duty (Per Unit)		CST/VAT (Per Unit)		Freight (Per Unit) (In Rs.)	Insurance (Per Unit) (In Rs.)	Total Price In Rs. (Per Unit) Col. No. (4+6+8+10+11+12)	Entry Tax @ ___% on Col. 13 (In Rs.)	All adjusted unit F.O.R. Destination Price including Entry Tax Col. No.13+14	Total Contract Value (In Rs.)
				Rate	Amt.	Rate	Amt	Rate	Amt.						
1.	2.	3.	4.	5.	6.	7.	8.	9.	10.	11.	12.	13.	14.	15.	16.

#### Notes:-

- i) The bidder is required to quote the prices in the above format only. Bids having prices quoted in other format/manner are liable to be ignored.
- ii) The bidder must fill each and every column of the above format. Mentioning “extra/ Inclusive” in any of the column may lead for rejection of the price bid.
- (iii) No cutting/ overwriting in the prices is permissible.
- (iv) The unit Ex-work price to be indicated in Col. No. 4 should be exclusive of taxes & duties which are to be indicated in separate columns meant for the purpose.
- (v) In case of price bid break-up is given component wise and also given sum total by the bidder but there is a difference between aggregate of component wise and sum total, then lesser of the two will be taken into account.

**Signature of bidder with rubber stamp**



**Schedule – V**

**JAIPUR VIDYUT VITRAN NIGAM LIMITED**

**A Govt. of Rajasthan Undertaking**

Statement of guaranteed technical particulars and other performance data for supply of .....  
(Name of material) against specification no.....

---

S.No. Particulars of technical & other performance data guaranteed.

---

---

Certified that we agree to all the aforesaid technical particulars and other performance data except following :-

---

S.No.	Particulars of technical & other Performance data	Reasons for deviations/departure.
-------	---------------------------------------------------	-----------------------------------

---

---

**(Signature)**  
Name & Designation  
with seal of the  
bidder.

**SCHEDULE-V-A****GUARANTEED AND OTHER TECHNICAL PARTICULARS OF  
DANGER PLATE AGAINST TN-4585**

(To be filled in by the bider and sent alongwith bid)

S.NO	PARTICULARS	
1.	MAKER'S NAME & ADDRESS	
2.	PLACE OF MANUFACTURE	
3.	IDENTIFICATION MARK	
4.	SPECIFICATION & STANDARDS:	
I)	GENERAL CHECKING	
II)	COLOUR ENAMELLING	
III)	RESISTANCE TO CITRIC ACID A) AT ROOM TEMPERATURE B) BOILING TEMPERATURE:	
IV)	LOW & HIGH VOLTAGE TEST FOR DETECTING AND LOCATING DEFECTS.	
V)	PRODUCTION OF SPECIMEN FOR TESTING .	
5.	THICKNESS OF M.S.PLATE	
I)	WITHOUT ENAMELLING	
II)	WITH ENAMELLING	
6.	DIAMETER OF HOLES	
7.	COLOUR ENAMELLS	
8.	MARKING	
9.	PACKING DETAILS	
I)	WEIGHT OF WOODEN CASE	
II)	NO. OF PLATES IN ONE CASE	
III)	GROSS WT. OF ONE CASE	

**Signature**  
**Name & Designation with seal of**  
**the firm**

**Schedule – VI (A)**

**JAIPUR VIDYUT VITRAN NIGAM LIMITED**

**A Govt. of Rajasthan Undertaking**

**DEPARTURE/DEVIATION FROM TECHNICAL SPECIFICATION**

The bidder shall state under this schedule the departure from the Purchaser's specification in respect of technical is as under:-

---

S.No.	Main Deviations from Technical Specification.
-------	-----------------------------------------------

---

---

Certified that we agree to all the technical specification of the NIT except for the deviation to the extent indicated above.

**(Signature)**  
Name & Designation  
with seal of the bidder.



**Schedule – VI (B)**

**JAIPUR VIDYUT VITRAN NIGAM LIMITED**

**A Govt. of Rajasthan Undertaking  
DEPARTURE FROM COMMERCIAL TERMS & CONDITIONS OF THE  
SPECIFICATION**

The bidder shall state under this schedule the departure from the Purchaser's specification in respect of Commercial terms & conditions:-

---

S.No.	Main Deviations from Specification.
-------	-------------------------------------

---

---

Certified that we agree to all the commercial terms & conditions as laid down in General Conditions of Contract to the specification except for the deviation to the extent indicated above.

**(Signature)**  
Name & Designation  
with seal of the bidder.



## Schedule – VII

**JAIPUR VIDYUT VITRAN NIGAM LIMITED**

**A Govt. of Rajasthan Undertaking**  
**LIST OF PAST SUPPLIES**

The bidder shall state under this schedule whether material and equipments, similar to those offered in the bid have been previously supplied by him. A list shall be given of such orders executed by him together with information regarding the names of purchasing organizations, quantities supplied and when the supplies were effected. This list should be in form given below:-

S.No. of Date	Detailed particulars of purchasing authority	Qty of items supplied	Order No. Completion	Name & details	Date &
1	2	3	4	5	6

If executed partially Remarks stipulated in order	whether still to be mentioned	Delivery to be executed
7	8	9

**Note:** Separate schedules are to be furnished by the bidder for past supply to the JVVNL, Jaipur other State Electricity Boards and other Departments /Organisations.

**(Signature)**  
 Name & Designation  
 with seal of the bidder.

**SCHEDULE-VIII****JAIPUR VIDYUT VITRAN NIGAM LIMITED****DELIVERY SCHEDULE****TN-4585**  
**PART – A**

The delivery Schedule of the material by the Purchaser Officer is as mentioned hereunder:-

<b>S.No</b>	<b>Particular Of Material</b>	<b>Commencement Period</b>	<b>Rate Of Supply per Month</b>	<b>Period for Completion of delivery of Entire material</b>
1	Danger Plates	30 Days from the date of receipt of detailed Purchase Order.	Equal Monthly Installments	Four Months after commencement period.

**Note – In case ordered quantity is different than quoted quantity, then monthly delivery shall be adjusted proportionately. Bids in which equal monthly delivery schedule is not indicated, shall be ignored.**

**PART - B**

In case bidder deviates from the delivery schedule mentioned by the purchaser in Part-A , then the delivery Schedule of the material by the bidder shall be indicated / mentioned as under:-

	<b>Particular Of Material</b>	<b>Commencement Period</b>	<b>Rate Of Supply per Month</b>	<b>Period for Completion of delivery of Entire material</b>

Note: (i) During the commencement period, the process of model assembly and submission of B.O.M. for approval shall be got completed.

(ii) During the commencement period the contractual formalities shall be got completed.

**Signature**  
**Name & Designation With Seal of the Bidder**



**Schedule – IX****JAIPUR VIDYUT VITRAN NIGAM LIMITED****A Govt. of Rajasthan Undertaking**

List of Equipments and Technical Hands Available with the Firm

(To be filled in by the bidders & enclosed with the bid)

Manufacturers and / or their authorized agents who are quoting against this bid are requested to furnish the following information along-with the bid. The Purchaser will have the discretion to ignore the bid without the under noted particulars and/or ignore the bid particulars.

1. Name and Address of Manufacturer.
2. Place where works exist.
3. Details of machinery particularly with B.H.P. of each item installed.
4. Details of staff employed in the works.
5. Date when started the manufacturing of item under reference.
6. List of items manufactured.
7. Literature and drawings of items manufactured showing their description, size, design and other important technical particulars.
8. Details of order so far, executed alongwith the names of organization to whom supplied.
9. Manufacturing capacity.
10. Is the workshop open for inspection by the representative of the board, if required?
11. Statement of financial resources and Banking Reference alongwith Balance-Sheet for previous two years.
12. Testing facilities available for the manufactured articles in the testing laboratory of works.
13. Whether the Firm is a small/medium/large scale industry.
14. Registration No. with :-
  - i. Small Scale, National/State.
  - ii. DGTD
  - iii. State Industries Department.

**(Signature)**

Name & Designation  
with seal of the bidder.

**Schedule - X****GENERAL PARTICULARS ABOUT THE BID IN BRIEF**

**JAIPUR VIDYUT VITRAN NIGAM LIMITED  
( PROCUREMENT CIRCLE)  
NEAR RAM MANDIR , BANI-PARK, JAIPUR-302006**

**TELEPHONE: - 0141 2208098  
2208098**

**TELE FAX: - 0141-**

**SPECIFICATION FOR SUPPLY OF DANGER PLATES  
AGAINST BID NOTICE NO. JPD/SE(Proc)/SPO.III/TN-4585**

<b>Last Date of receipt of bids</b>	<b>19.12.2016 upto 2:30 PM</b>
<b>Date of opening of bids</b>	<b>20.12.2016 at 3:00 PM</b>
<b>Cost of Specification</b>	<b>Rs.2500.00 ( Rs. Two Thousand Five Hundred only)</b>
<b>Validity</b>	<b>120 days from the next date of opening of tender.</b>
<b>Earnest Money</b>	<b>Rs. 50,000.00 (Rs. Fifty Thousand only) / Exemption Certificate / Vendor Registration Of Class "E" Category or above.</b>

**Note:-** The bidder, in their own interest, are requested to read very carefully Section-I (Instruction to bidders), Section-II (General Condition of Contract) & Section-III (Technical Specification) before filling the bid. The Bid documents be downloaded from JVVNL website [www.jaipurdiscom.in](http://www.jaipurdiscom.in) . No hard copy of the bidding documents will be provided to the bidders through this office. In case of any discrepancy found in bidding documents downloaded from the website and appended with the bid (as a bid document) and original copy of such document available in the office of Superintending Engineer (Proc.), Jaipur Discom, Jaipur then the copy available with Superintending Engineer (Proc.), Jaipur Discom, Jaipur will be considered as final document for all purpose. The cost of Bid document as published in NIT shall be furnished along with downloaded bid document in the manner prescribed in bid document.

1. Furnishing of proof of deposition of cost of bid document, Earnest money/ exemption certificate as per Clause 1.03 & 1.16 of section-I (Instructions to bidders) along with downloaded bid documents is essential otherwise the " BID OFFER " will not be opened. However the bidder(s) who get themselves registered with JVVNL as per clause No. 1.5.3 of Section-II ( General Conditions of contract) before submitting of bid documents against

the bid enquiry for supply of quoted items under appropriate category are not required to furnish Earnest money deposit. They shall furnish the proof of such valid registration with their bid. Cost of Bid document shall be furnished in the form of Crossed bank draft/ banker's cheque payable in the name of " **ACCOUNTS OFFICER (MM), JVVNL, JAIPUR**. EMD if required shall be furnished in accordance with the clause No. 1.03.1 of Section-I(Instructions to bidders).

2. The Central and State Govt. Undertakings are exempted from furnishing of Earnest money subject to furnishing of such certificate / documentary evidence in support of their being Govt.(Central/State) undertaking.

3. The bidder(s) shall **quote prices strictly in the manner prescribed in Clause 1.09 of Section-I** (Instructions to bidders). & Clause No. 1.33 Section-II (General Conditions of contract) **in Schedule-IV, otherwise their bid is liable for rejection. The prices quoted should be FIRM.**

4. The bid offer shall be furnished in **Single Part** in the following manner:

i) **First envelope containing proof of deposition of cost of Bid documents & EMD.** Name of item, bid no., time of bid submission, due date for opening of bid and the word 'Envelope-I & Cost of bid documents and Earnest Money / Valid Registration Certificate under relevant class / A certificate of being a Rajasthan / Central Govt. undertaking' should be clearly written on the front side of the envelope.

ii) **Second envelope for techno-commercial bid.** Name of item, bid no., time of bid submission, due date for opening of bid and the word 'Envelope – II & Techno-Commercial Bid' should be clearly written on the front side of the envelope.

iii) **Third envelope for price bid.** Name of item, bid no., time of bid submission, due date for opening of bid and the word 'Envelope – III & Price Bid' should be clearly written on the front side of the envelope.

*Note*: Envelope III containing price bid will be kept in the safe custody of the concerned engineer / officer. It will be opened at a later date in respect of those bidders whose offers are found / adjudged technically and commercially acceptable. The date of opening of "Price Bid" shall be intimated to successful bidders in due course of time. In case of deviation from the stipulated clauses of bid specifications, price bid of the bidder will not be opened.

iv) **Fourth envelope containing above three envelopes.** Name of item, bid no., time of bid submission and due date for opening of

**bid should be clearly written on the front side of the envelope. (All the above envelopes shall be duly sealed individually).**

***Note*** : Separate price bid and technical bid are required to be submitted incase total bid value exceeds Rs. 50 Lacs and if the same is upto 50 Lacs, technical bid and price bids shall be submitted in a single envelope. **However, two part bidding could be adopted for the item of special nature technology, sophistication or for any other item in the opinion of purchasing officer considered suitable for two part bidding system also irrespective of value.**

- v) The bidder(s) shall ensure that their bids are furnished /submitted strictly in the manner detailed in the specification.

( PLEASE NOTE THAT BID RECEIVED AFTER SPECIFIED TIME ON DUE DATE OF OPENING WILL NOT BE ACCEPTED AND SUCH OFFERS SHALL BE IGNORED.)

5. The bids not accompanied with pre qualifying requirement , technical requirement indicated in the specification and other requirement given here under will be considered as incomplete offer and sufficient grounds for offer to be passed over:

- i) Capacity, capability and competency proofing documents.

a) Capacity/orders of similar and higher rating of bided equipment booked as on date of bidding with type and rating and construction details of equipment for which order received be indicated.

b) Copy of purchase orders of Erstwhile RSEB or JVVNL for similar or higher rating equipment latest executed.

i) Year wise past experience for last 5 years of similar or higher rating of bided equipment.

ii) The details of testing facilities available at the works and copies of latest type test certificates, carried out on similar or higher rating.

iii) Quality assurance plan.

iv) Complete guaranteed technical particulars, out lines and general arrangement drawings alongwith Bill of Material.

6. Bids without Sections & schedules as mentioned in index shall be rejected.

7. Bids shall be furnished in single copy.

8. JVVNL has the right to reject any offer on the basis of track record of poor performance in execution of previous order / equipment supplied / after sales service while evaluating the Techno-commercial bid.

9. JVVNL reserves the right to accept minor deviations in standard terms and conditions and also in technical and constructional features as specified in the technical specification (Section-III).

10. Deviation of any kind shall not be quoted in price bid, if found quoted, the same shall be ignored.


11. The following facilities are to be provided by the supplier at his own cost to the inspecting officer of JVVNL.

i) Suitable accommodation.

ii) Local conveyance between arrival point, place of stay, works and departure point.

iii) The supplier shall assist in arranging return ticket and reservation on the request of the inspecting officer for which the payment shall be made by the inspecting officer. In case of joint inspection, single or shared double room accommodation shall be provided.

TN-4585




Drawing No. JVVNL / S.E. (Prd.) / SPO-II / TN- 4585

- Note 1 - All lettering should be centrally spaced.
- Note 2 - The dimensions for the words in district language are mainly for guidance, however, care should be taken to space them centrally between the edges and the area of the skull and bones.
- Note 3 - The location of the fixing bolts shall be left to the choice of the user.
- Note 4 - 11 000 volts is just specimen, actual voltage is to be lowered for different system voltages.
- Note 5 - The corners of the plates should be rounded off.

All dimensions in millimeters.

TN. 4585/1



Drawing NO. 11111/1.S.E./  
SPO II/TN- 4585

NOTE 1 - All letterings should be centrally spaced.  
 NOTE 2 - The dimensions for the words in district language are mainly for guidance, however, care should be taken to space them centrally between the edges and the area of the skull and bones.

NOTE 3 - The location of the fixing holes shall be left to the choice of the user.  
 NOTE 4 - 11 000 volts is just specimen, actual voltage is to be inserted for different system voltages.  
 NOTE 5 - The corners of the plate should be rounded off.

All dimensions in millimetres.