

JAIPUR VIDYUT VITRAN NIGAM LIMITED
OFFICE OF THE SUPERINTENDING ENGINEER (MM)
OLD POWER HOUSE PREMISES, BANI PARK, JAIPUR - 302006
PH:0141-2202607 FAX.: 0141-2202025

NO.JPD/SE/MM/SPO-IV/TN-2452/D. 7446

DATED: 27/12/17


CORRIGENDUM No. 1**TN-2452****(TENDER ENQUIRY FOR PURCHASE OF 36 KV OUTDOOR VCB KIOSKS AGAINST TN-2452)**

The Addendum /Corrigendum in the above technical specification is issued as under:-

Technical Specification (Section-III)

Following clauses are hereby amended to be read as under:-

| S. No | Cl. No. | Existing Provision | To be read as under |
|-------|---|---|---|
| 1 | Cl No.: 4.0 (Technical Specification) | clause No.: 4.1.19: Rated Breaking Capacity-30KA 4.1.10 Rated making capacity-2.50X30KA | clause No.: 4.1.19: Rated Breaking Capacity-25KA 4.1.10 Rated making capacity-2.50X25KA |



(R.K.MEENA)

SUPERINTENDING ENGINEER (MM)

Copy forwarded to the Superintending Engineer (IT), Jaipur Discom, Jaipur for arranging the hosting of above corrigendum at Nigam's website.



SUPERINTENDING ENGINEER (MM)

