

**JAIPUR VIDYUT VITRAN NIGAM LIMITED**  
**OFFICE OF THE SUPERINTENDING ENGINEER (MM)**  
**OLD POWER HOUSE, NEAR RAM MANDIR, BANI PARK, JAIPUR**

No:JPD/SE/MM/SPO-VI/D. 8185

Dated: 01/02/18

**CLARIFICATION**

**TN-2478**

**(Tender ID 2018\_JVVNL\_92094\_1)**

**(Purchase of 5 KVA, Single Phase Aluminium wound Distribution Transformers with ICB BIS Level-2)**

- 1. The Technical Cum Identification Plate Clause No. 8(A) of the specification is hereby amended as under:**

<b>Earlier</b>	<b>Now</b>
M.S. plate of size 125 x 75 x 2.5 mm having following details punched with letters of size 8mm X 6mm shall be continuously welded to the main tank body and on top cover of tank in clearly visible position.	M.S. plate of size 125 x 75 x 2.5 mm having following details punched with letters of size 8mm X 6mm shall be continuously welded to the main tank body in clearly visible position.

*[Signature]*  
01/02/18  
**(R. K. MEENA)**

Superintending Engineer (MM)  
Jaipur Discom, Jaipur

Copy forwarded to the Superintending Engineer (IT), Jaipur Discom, Jaipur for arranging hosting of the above corrigendum on JVVNL, Portal.

*[Signature]*  
01/02/18  
Superintending Engineer (MM)

*[Signature]*