

JAIPUR VIDYUT VITRAN NIGAM LIMITED  
OFFICE OF THE SUPERINTENDING ENGINEER (MM-II)  
OLD POWER HOUSE PREMISES, BANI PARK, JAIPUR - 302006  
PH:0141-2202607 FAX.: 0141-2202025

NO.JPD/SE/MM-II/SPO-IV/TN-2502/D. 8044

DATED: 16-01-2019

**CORRIGENDUM No. 1**  
**TN-2502**

(TENDER ENQUIRY FOR PURCHASE OF A.C. STATIC THREE PHASE, FOUR WIRE, HAVING DLMS PROTOCOL WITH OPTICAL & ADDITIONAL LPRF PORT 10-60A RATING WHOLE CURRENT, CLASS 1.0 ACCURACY, KWH ENERGY METERS HAVING POLYCARBONATE METER CASE AND BACKLIT LCD DISPLAY AGAINST TN-2502)

The Corrigendum in the above technical specification is issued as under:-

**Technical Specification (Section-III)**

Following clauses are hereby amended to be read as under:-

Sr. No	Clause No	Particulars	To be read as under:-
1.	Cl 12. D. iv	In addition to above selected samples, two lot of <b>three sample of meter with meter Box</b> and two lot of samples of 6 Kg. raw material of each of meter case, Meter Box and terminal block shall be drawn by the inspecting officers during the 1st inspection & sealed by the aforesaid procedure which shall be sent to CIPET/ any NABL accredited test house for verification of properties of plastic material used for base and cover of meter case (base & cover), Meter Box & Terminal Block as mentioned at clause 7.1 & 7.2 of specification.	In addition to above selected samples, two lot of <b>three sample of meter</b> and two lot of samples of 6 Kg. raw material of each of meter case, Meter Box and terminal block shall be drawn by the inspecting officers during the 1st inspection & sealed by the aforesaid procedure which shall be sent to CIPET/ any NABL accredited test house for verification of properties of plastic material used for base and cover of meter case (base & cover), Meter Box & Terminal Block as mentioned at clause 7.1 & 7.2 of specification.
2.	Volume A- 16.0 (a) Samples along wuth Bid <b>AND</b> Schedule-III-A (VI)	The bidder shall furnish <b>Eight meters and one meter box</b> conforming to this specification duly sealed along with routine test certificates in the office of SE(MM),JVVNL, Jaipur one day prior to the date of opening of Tender. If the samples are not received, the bid shall be considered as Non-responsive	The bidder shall furnish <b>Eight meters</b> conforming to this specification duly sealed along with routine test certificates in the office of <b>SE(MM-II),JVVNL</b> , Jaipur one day prior to the date of opening of Tender. If the samples are not received, the bid shall be considered as Non-responsive

dm  
16/1/19  
(R. K. MEENA)

SUPERINTENDING ENGINEER (MM-II)

Sr

Copy forwarded to the following for information or necessary action:

- 1) the Chief Engineer(MM) Ajmer Discom/ Jodhpur Discom, Ajmer/Jodhpur for information.
- 2) the Superintending Engineer (IT), Jaipur Discom, Jaipur for arranging the hosting of above corrigendum at Nigam's website.
- 3) the Superintending Engineer (M&P), Jaipur Discom, Jaipur for information.

*dm*  
16/11/19

SUPERINTENDING ENGINEER (MM-II)

*sa*