

JAIPUR VIDYUT VITRAN NIGAM LIMITED
OFFICE OF THE SUPERINTENDING ENGINEER (MM-II)
OLD POWER HOUSE PREMISES, BANI PARK, JAIPUR - 302006
PH:0141-2202607 FAX.: 0141-2202025

NO.JPD/SE/MM-II/SPO-IV/TN-2510/D. 8666

DATED: 24-01-2019

CORRIGENDUM No. 1

TN-2510

(TENDER ENQUIRY FOR PURCHASE OF 33 KV CT AGAINST TN-2510)

The Addendum/Corrigendum in the above technical specification is issued as under:-

Technical Specification (Section-III)

Following clauses are hereby amended to be read as under:-

Sr. No	Clause no.	Particulars	To be read as under:-
1.	3.12 (ii)	In the event of order, supplier shall have to get all type test conducted as per requirement of relevant standards on one sample out of first lot comprising minimum 25% of ordered quantity of lowest ratio CT's in presence of inspecting officer without any extra cost, at CPRI/ NABL accredited testing laboratories designated by purchaser for which facilities exists in India unless otherwise it is waived by the purchaser.	In the event of order, supplier shall have to get all type test conducted as per requirement of relevant standards on one sample out of first lot comprising minimum 25% of ordered quantity of lowest ratio CT's in presence of inspecting officer without any extra cost, at CPRI/ NABL accredited testing laboratories designated by purchaser for which facilities exists in India unless otherwise it is waived by the purchaser. The supplies shall only be accepted & payment against supplies shall be released only after receipt of successful type testing for all type tests on sample.
2.	3.12 (viii)	----	In case of failure in type tests, following provisions shall be applicable: - Failure in type tests In the event of failure/ unsatisfactory results of the CTs in type test, the supplier shall, however, be allowed to check the reasons of failure and if need be, to improve/ modify the design, further supplies, including replacement against supplies already made (if any), shall be accepted only after successful type test(s) are arranged on the fresh CTs selected by the purchaser. Charges for such test(s) shall be borne by the supplier. However, in the event of failure of CTs, in the repeat type test, the Purchaser (JVNL) may cancel the order and other action be taken as per GCC.

(R. K. MEENA)

SUPERINTENDING ENGINEER (MM-II)

- 1) Copy submitted to the Chief Engineer(MM) Ajmer Discom/ Jodhpur Discom, Ajmer/Jodhpur for information.
- 2) Copy forwarded to the Superintending Engineer (IT), Jaipur Discom, Jaipur for arranging the hosting of above corrigendum at Nigam's website.
- 3) Copy also forwarded to the Superintending Engineer (M&P), Jaipur Discom, Jaipur for information.

dm 24/11/19
SUPERINTENDING ENGINEER (MM-II)

(2) *72*