

JAIPUR VIDYUT VITRAN NIGAM LIMITED

OFFICE OF THE SUPERINTENDING ENGINEER (M&P), JAIPUR DISOCM, JAIPUR

Chambal Power House, Hawasarak, Jaipur – 302019. Tel:0141-2296651 :: Fax:0141-2290395::

Website: www.energy.rajasthan.gov.in/jvnl :: Email: semeters@yahoo.in

No. JPD/SE(M&P)/SEC III(B)/TN-M&P-12/ D. 613 Jaipur, dt. 4.5.18

CORRIGENDUM

The following approved amendments/ modifications are hereby made in tender specification of TN:M&P-12 as decisions taken by the committee members on dated 23.04.18 on the queries raised by bidders regarding tender for Supply and Erection of High Impedance Frequency Relays for 12 KV Outdoor VCB Kiosk on turnkey basis in JPDC Circle under JVNL against TN-M&P-12. The bidders are advised to go through the following amendments/ modifications in referred page/referred clauses in RFP uploaded under TN-M&P-12.

| S. N | RFP page no./Reference Clause | As per RFP | Bidders Query | Decision of the Technical Committee |
|------|---|--|--|---|
| 1. | Page 23 Section-II (Eligibility Criteria) | The Bidder has its own NABL accredited R&D center/Lab. | We certify that all of the testing instruments used during production and testing of our relays are certified by NABL accredited lab only. 2. All of our products are designed as per compliance to IEC 60255 and IEC 61000. 3. We strictly follow ISO 9001/2008 in all the process adopted during manufacturing/Testing of our products. (Enclosed Certificate No.1015-2006-AQ-IND-RVA) 4. Our in-house Testing Lab is certified by MINISTRY OF SCIENCE and TECHNOLOGY; GOVT. OF INDIA. (Pls refer enclosed letter bearing No. TV/IV-RD/3130/2016 Dated 21/04/2016 and Valid upto 31.03.2019 as all NABL accreditation body comes under MINISTRY OF SCIENCE & TECHNOLOGY (Govt Of India). Therefore in context of above, we humbly request you to kindly amend this clause. | The Bidder has its own Govt. recognized R&D center /Lab and certificate of which should be provided. Agreed to Amended as:- |

| | | |
|---|--|--|
| <p>Page 61</p> <p>Guaranteed Technical Particular</p> | <p>Bidder to validate the GTP provided here with the certificate of any accredited lab, the certificate no. shall be appropriately provided in the "Bidder Comment" column for quick correlation</p> | <p>Offered relays are type tested and Agreed to Amended as:- Bidder to validate the GTP provided here and provide the type test certificate of product from any accredited lab, the certificate no. shall be appropriately provided in the "Bidder Comment" column for quick correlation.</p> |
|---|--|--|

(Anil Gupta)
 Superintending Engineer (M&P)

Copy forwarded/submitted to the following for necessary information and action :-

1. The Zonal Chief Engineer (J/Z), Jaipur Discom, Jaipur.
2. The Addl. Chief Engineer (M&P-IT), Jaipur Discom, Jaipur.
3. The Chief Acc. officer (IA), Jaipur Discom, Jaipur.
4. The Superintending Engineer (IT), Jaipur Discom, Jaipur for arranging hosting at Nigam Website (www.energy.rajasthan.gov.in/jvvn1).

Superintending Engineer (M&P)