

**Office of the  
Chairman Discoms  
Vidyut Bhawan, Jyoti Nagar, Jaipur -302005  
Phone Office :0141-2744965, Fax-2744187**

---

No.Chairman Discoms /F.TA/D: 153. Jaipur, Dated : 05/8/16.

**STANDING ORDER No.16/01-A  
MEASURES FOR LOSS REDUCTION**

Whereas Discoms have already adopted a road map for reduction in the distribution loss in the rural areas, urban areas and industrial areas for which certain technical interventions are being made in respect of existing infrastructure and domestic and other connections, it is equally necessary that proper practices are adopted in respect of future installation of infrastructure as well as release of connections so that the new works do not contribute to the possibility of theft of electricity. Accordingly the instructions are hereby issued for strict compliance by Discom.

1. The domestic connections should not be released in the rural areas without piercing connector in the AB cable.
2. The armoured cable is invariably adopted as a service line.
3. Both ends of the armoured cable i.e. the connector end and the meter end should be so connected that the water does not enter the cable and the naked wire of the armoured cable are not exposed outside the meter / connector.
4. The new installation of single phase transformer as well as three phase transformer are proper with welded cubical & MCCB and the earthing is adequate.
5. For demonstration purpose, in each sub-division, sample installation of three phase transformer, single phase transformer and domestic connections should be there so that the manpower in the field may see these sample installations and adopt the right

practice in the field. These sample installation should be ready by 1<sup>st</sup> Sept 2016.

6. 11KV rural feeder should be classified in terms of voltage regulation more than 8% or within 8%. On the feeders where VR is high, augmentation be undertaken in a time bound manner. MDs of Discom will prepare a plan.

  
(Shreemat Pandey)  
Chairman Discoms  
05/8/2016

**Copy to the following for information and necessary action:-**

1. CE/ ACE (MM/DDUGJY/M&P/IT/PPM/Comml), Jaipur/ Ajmer/ Jodhpur Discom.
2. ZCE Jaipur/Ajmer/Jodhpur Discom.....
3. SE (O&M/Vig/Comml/M&P/TW/Plan/IT/MM/Proc./RE), Jaipur/ Ajmer/ Jodhpur Discom, Jaipur/Ajmer/Jodhpur.
4. ASP (Vig.), Jaipur/Ajmer/Jodhpur Discom, Jaipur/Ajmer/Jodhpur
5. CAO (Cont./Revenue/FM)/Consultant (ATR), Jaipur/Ajmer/Jodhpur Discom.....
6. Secy. (Admn.) Jaipur/Ajmer/Jodhpur Discom.
7. Company Secretary, Jaipur/Ajmer/Jodhpur Discom
8. PS to Pr. Secy. Energy, GoR, Jaipur
9. PS to Advisor-Energy, GoR, Jaipur
10. TA to MD Jaipur/Ajmer/Jodhpur Discom.
11. PA to Dir. (Tech/Fin), Jaipur/Ajmer/Jodhpur Discom.
12. Media consultant/PRO, Jaipur/Ajmer/Jodhpur Discom.....

  
5/8/16  
**SE-TA to Chairman Discoms**