

**JODHPUR VIDYUT VITRAN NIGAM LIMITED**

No.JdVVNL/MD/CE(C&amp;P)/SE(RA&amp;C)/JU/2008-09/D. 04 Dt. 01.04.09

**ORDER**

**Sub: Installation of 11KV "Ring Main Unit" (RMU)/11KV "Ring Main Switch Fuse Unit" for termination of 11 KV underground service line.**

On the subject cited above, order No.2118 dtd.28-01-09 (Comml.JDP/473) was issued for providing "Ring Main Unit" (RMU)/ Ring Main Switch Fuse Unit for termination of 11 KV underground service lines in the premises of prospective HT consumers under all categories in Jodhpur City by such consumers.

For implementing above directions, difficulties are being faced by the field officers for small consumers upto 500 KVA. The matter was again examined and I am directed to convey the approval of the CMD for following below mentioned procedure in super session to order No.2118 dtd.28-01-09 (Comml.JDP/473):

- a) Consumers having contract/design demand between 50 KVA to 125 KVA be allowed to lay underground cable service line from nearest JdVVNL supply point and 11 KV oil switch may be installed in consumer's premise before transformer.
- b) At locations where JdVVNL has already installed RMU consumers having contract demand/Designed demand more than 125 KVA may be allowed to install 11 KV RMU with fuses without isolators (both sides extensible) of the same make as installed by JdVVNL. In such cases, fuses are to be replaced by consumers.
- c) Consumers having demand more than 125 KVA at locations other than (b) be allowed to use 11 KV RMU having fuses where fuses are to be replaced by consumers.

By Order,

*4/1*  
**(M.S. FAGERIA)**  
**CHIEF ENGINEER(C&P)**  
**JODHPUR DISCOM:JODHPUR**

Note: The order is also available on Jodhpur Discom's website [www.jdvvn.com](http://www.jdvvn.com)/[www.rajenergy.com](http://www.rajenergy.com)