

**JODHPUR VIDYUT VITRAN NIGAM LIMITED**

No.JdVVNL/MD/CE(C&P)/SE(RA&C)/JU/2009-10/D. 110 Dt. 17.04.09

ORDER

**Sub: Clarification regarding Order Comml.JDP/488.
Installation of Dry/Oil type transformer in
residential/commercial buildings and their testing in
Nigam's Central Testing Laboratory.**

On the subject, some doubts have been raised by the field officers as well as by the transformer manufacturers regarding implementation of above order. In this connection, it is to inform that the matter has been examined and following clarifications are issued for right implementation of the said order:-

- i) The Order No.2443 dtd.20-03-09 (Comml.JDP/488) would be effective in respect of the applications for new connections/load extension received on or after 01-03-09 in the sub divisions.
- ii) Losses as prescribe in Annexure-A of Comml.JDP/488 are applicable for all transformers whether copper or aluminum wound.
- iii) CTL will test only no load loss as well as full load loss and compliance of balance parameters as prescribed in Annexure-A of the said order, shall be the responsibility of applicant/manufacturers.
- iv) Cases where H.T. metering has been deployed i.e. losses are to be borne by the consumer, the CTL will not test such Distribution transformers but the applicant is expected to follow the parameters, as prescribed in Annexure-A of Comml.JDP/488.

It is further stated that the matter of cases of existing connections, is still under examination and shall be decided at the earliest possible.

By Order,


(S.K. KULSHRESTHA)
CHIEF ENGINEER(C&P)
JODHPUR DISCOM:JODHPUR

Note: The order is also available on Jodhpur Discom's website www.jdvvn.com/www.rajenergy.com