

**JODHPUR VIDYUT VITRAN NIGAM LIMITED**

No.JdVVNL/MD/CE(HQ)/SE(RA&C)/JU/2009-10/D.2503Dt. 18.01.10

CIRCULAR**Sub: Release of domestic connections for scattered house holds near the fields.**

Various orders were issued regarding release of domestic connections in scattered area(s) in villages. With the implementation of FRP schemes, the scattered house holds near the fields who were earlier getting domestic supply in the prescribed single phase hours stopped getting domestic supply beyond agricultural block hours.

In order to circumvent the problem, it was decided that all such existing domestic connections be released by installation of single phase transformer of smaller capacities and a scheme for release of connections of domestic light in scattered area (s) was introduced. Salient features of scheme for release of domestic connections for scattered area are given hereunder:-

1. Single phase network is laid for release of connections to such scattered consumers near the fields.
2. The use of single phase distribution transformer in inhabited scattered rural areas is restricted only for domestic light and fan purpose having sanctioned connected load maximum upto 0.5 KW.
3. The total extension of LT Line from each such 5 KVA single phase distribution transformer is limited to radial distance of 500 meters.
4. Single phase 5 KVA Distribution transformer in the scattered area is installed outside the house of first applicant (in order of priority) and an undertaking for security against its theft/theft of oil, coils etc. of distribution transformer is required to be obtained on Non judicial stamp paper from him i.e. first applicant.
5. Such connections are to be released through AB Cable and tapping of consumer is through armoured PVC cable.
6. PCC poles of 9 meter length are used.
7. A sum of Rs.3500.00 is recovered from the consumer for release of such connection.
8. The maximum number of connections on the 5 KVA single phase distribution transformer is limited to 4 (four) as per the prescribed norms. For example, if on any 5 KVA single phase distribution

transformer, the number of existing DL connections is 2 then only two more connections can be released for scattered area from that particular transformer.

It is, therefore, quite clear that for release of connections in the scattered area scheme, the following is not permissible/allowed:

- i) The capacity of existing 5 KVA distribution transformer is not to be augmented for release of more domestic light connections.
- ii) In no case, the 11 KV Line from the existing DP of 5 KVA transformer is to be extended for release of more domestic light connection in the scattered area. In other words, no new distribution transformer is to be installed by extending the existing 11KV line for release of such connections.
- iii) If due to non availability of 5 KVA, DT higher capacity DTs were installed say 16 KVA capacity, these transformers are to be considered as, 5 KVA transformers for the purpose of release of maximum four connections. Such higher capacity DTs should be replaced by 5 KVA transformers in due course of time.

By order,


18/11/2010
(M.L. TRIPATHI)

**DY. CHIEF ENGINEER (HQ)
JODHPUR DISCOM: JODHPUR**

Note: The order is also available on Jodhpur Discom's website www.jdvvn1.com/www.rajenergy.com

Copy Submitted/ forwarded to the following for information and necessary action:

- 1) The Principle Secretary (Energy), Govt. of Rajasthan, Jaipur.
- 2) The District Collector, Jodhpur / Pali / Barmer / Churu / Jalore / Sriganganagar / Hanumangarh / Bikaner / Sirohi.
- 3) The Director (Finance), Jodhpur Discom, Jodhpur.
- 4) The Director (Technical), Jodhpur Discom, Jodhpur.
- 5) The Chief Engineer/Zonal Chief Engineer (O&M-JDZ/BKZMM), Jodhpur Discom, Jodhpur/ Bikaner.
- 6) The Chief Accounts Officer(A/cs & Rev/IA/Ways & Means), Jodhpur Discom, Jodhpur/Jaipur.
- 7) The T.A. to Chairman & Managing Director, Jaipur Discom Jaipur, for kind perusal of the Hon'ble C&MD.
- 8) The T.A. to Managing Director, Jodhpur Discom / Ajmer Discom, Jodhpur / Ajmer, for kind perusal of the Hon'ble MD.
- 9) The Superintending Engineer (CC / DC / O&M / BFL / PP&M / TW / M&P/ MM&C/RDPCC), Jodhpur Discom, Jodhpur / Pali / Barmer / Churu / Jalore / Sriganganagar / Hanumangarh / Bikaner / Jaisalmer/Jaipur.
- 10) The Personal Secretary to Energy Minister, Secretariat, Jaipur for kind perusal of Hon'ble Energy Minister, Govt. of Rajasthan, Jaipur.
- 11) The O.S.D. (Monitoring), Govt. of Rajasthan, Jaipur.