



No.JdVVNL/MD/CE(HQ)/SE(RA&C)/JU/2015-16/D. 569 Dt. 26.05.15

ORDER

Sub: Releasing of Single Phase Connection to Domestic/ Non-Domestic consumers upto 10KW connected load.

The matter of releasing single phase connection to Domestic/Non-domestic consumers upto 10KW connected load was discussed in 60th meeting of DCF held on 07.05.2014 and 63rd meeting of DCF held on 28.11.2014 and following decision were taken:

60th meeting held on 07.05.2014:

“The DCF directed that single phase electric connection upto 10KW Domestic and Non-Domestic applicants may be allowed in exceptional circumstances in rural area subject to condition that separate transformers will be installed for each connection and entire cost of 11KV line and transformers will be borne by applicant. Also connection will be released by installing AMR System.”

63rd meeting held on 28.11.2014:

“The DCF decided that all single phase connections under Domestic/Non-Domestic category upto 10KW connected load in rural areas shall be released only with AMR System(Meter, Modem and Communication System) and the consumer's would bring their own AMR System.”

In pursuance to above decision order No.Comml.JDP/653 dated 06.06.2014 and order No.Comml.JDP/666 dated 09.01.2015 were issued.

The matter again reviewed in 64th DCF meeting held on 08.05.2015 and DCF decided not to allow the release of single phase electric connection to Domestic/Non-domestic consumers for load more than 5KW.

In light of above, the orders issued in this regard vide Comml.JDP/653 dated 06.06.2014 and order No.Comml.JDP/666 dated 09.01.2015 are hereby withdrawn with immediate effect and henceforth single phase electric connection to Domestic/Non-domestic consumers shall be released upto 5KW connected load only.

By order,



(M.R. VISHNOI)

**CHIEF ENGINEER (PC-C&P)
JODHPUR DISCOM:JODHPUR**