



No.JDVVN/MD/CE(HQ) SE(RA&C)/JU/2015-16/D. 1327 Dt. 28.07.15

ORDER

Sub: Clarification regarding provisions of Net Metering and Grid connectivity of Grid Connected Rooftop and Small Photovoltaic Systems.

**Ref: 1. RERC Net Metering Regulation-2015
2. Comml.JDP/682 dtd.17.04.2015
3. RERC order dt.30.06.2015**

The detailed guidelines & procedure for Net Metering and Grid Connectivity of Grid Connected Rooftop & Small Solar Photovoltaic System has been issued vide Comml.JDP/682 dt.17.04.2015. Subsequently difficulties were reported in the implementation of the certain provisions of the regulation by the field officers and matter was referred to RERC for clarifications. The RERC vide their order dt.30.06.2015 has clarified the same and accordingly these clarifications may be read in continuation to the Comml.JDP/682 under respective clauses as under.

1. In the clause F(2) table Sr.1 may be read as under.

S. No.	Connected Load of Eligible Consumer	Connectivity Level
1.	Upto 5KW	240V-Single Phase/ 415V-Three Phase as per connectivity level

2. In the Annexure IX table Sr. No.5 may be read as under.

(a) Meter for Solar Generation Measurements:

S. No.	Technical Parameters	Connectivity at 415 V & below voltage level	Connectivity at above 415V voltage level
		Whole Current Meters	CT operated CT-PT operated
5.	Current Rating	10-60	10-60 5 Amp. 5 Amp.

(b) Meter for Net Generation Measurements:

S. No.	Technical Parameters	Connectivity at 415 V & below voltage level	Connectivity at above 415V voltage level

	W. & C. operated		CT operated	CT-PT operated
5. Current Rating	10-60	10-60	5 Amp.	5 Amp.

By order.

(ASHOK MATHUR)

**SUPERINTENDING ENGINEER (RA&C)
JODHPUR DISCOM:JODHPUR**

Copy Submitted/ forwarded to the following for information and necessary action:

- 1) The Principle Secretary (Energy), Govt. of Rajasthan, Jaipur.
- 2) The District Collector, Jodhpur / Pali / Barmer / Jalore / Sirohi/ Jaisalmer/ Sriganganagar / Hanumangarh / Bikaner/Churu.
- 3) The Director (Finance/Technical), Jodhpur Discom, Jodhpur.
- 4) The Zonal Chief Engineer (O&M-JDZ/BKZ/BMR), Jodhpur Discom, Jodhpur/ Bikaner/Barmer.
- 5) The Addl. Chief Engineer(IT-Trg, MM&C/RGGVY), Jodhpur Discom, Jodhpur.
- 6) The Chief Accounts Officer(A/ces & Rev /IA Ways & Means), Jodhpur Discom, Jodhpur/ Jaipur.
- 7) The T.A. to Chairman & Managing Director, Jaipur Discom Jaipur, for kind perusal of the Hon'ble C&MD.
- 8) The T.A. to Managing Director, Jodhpur Discom / Ajmer Discom, Jodhpur / Ajmer, for kind perusal of the Hon'ble MD.
- 9) The Company Secretary, Jodhpur Discom, Jodhpur.
- 10) The Superintending Engineer (CC / DC / O&M / BFL / PP&M / TW / M&P/ MM&C/ RDPCC), Jodhpur Discom, Jodhpur / Pali / Barmer / Sirohi / Jalore / Jaisalmer/ Sriganganagar / Hanumangarh / Bikaner / Chura/ Jaipur.
- 11) The Superintending Engineer(IT), Jodhpur Discom, Jodhpur for putting up the order on the website of Discom.
- 12) The Personal Secretary to Energy Minister, Secretariat, Jaipur for kind perusal of Hon'ble Energy Minister, Govt. of Rajasthan, Jaipur.
- 13) The O.S.D. (Monitoring), Govt. of Rajasthan, Jaipur.
- 14) The TA to Ombudsman, Vidhyut Viniyamak Bhawan, Sahakar Marg, Near State Motor Garage, Jaipur, for kind perusal of Ombudsman.
- 15) The Addl. S. P. (Vigilance), Jodhpur Discom, Jodhpur With spare copies for distribution amongst vigilance officers.
- 16) The Sr. Accounts Officer/Accounts Officer (O&M-CC / DC - Comml. / Audit/ Rev), Jodhpur Discom, Jodhpur / Bikaner.
- 17) T.A. to Chief Engineer(PC-C&P), Jodhpur Discom, Jodhpur
- 18) The Executive Engineer (O&M/DD...../A-B-C-Zone/City-I-II/ I.C/ IA/ Training/ Vigilance), Jodhpur Discom..... **for distribution amongst all the AENs/JENs/ARO under your control.**
- 19) The Public Relation Officer, Jodhpur Discom, Jodhpur.
- 20)

**SUPERINTENDING ENGINEER (RA&C)
JODHPUR DISCOM:JODHPUR**