



No.JdVVNL/MD/CE(HQ)/SE(RA&C)/JU/2017-18/D. 449 Dt. 04.07.17

**ORDER**

**Sub: Regarding non-requirement of Electrical Inspector Certificate/ Self certification of installation in case of increase /decrease of load /demand.**

In compliance to the notification No. F.23 (3) Energy /2015 dated 21.03.2016 issued by Energy Department, GoR and CEA (Measures relating to safety and Electric Supply) Regulation, 2010, every electrical installation upto 33 KV and 11 KV voltage level shall be inspected, tested and shall be self-certified by the owner of the installation with the assistance of Chartered Electrical Safety Engineer before commencement of supply or recommencement after shutdown for six months and above for ensuring observance of safety measures.

In this regard, it is clarified that in the event of increase/ decrease in connected load/ contract demand where no alteration in the existing 11 KV or 33 KV installation is required, there is no need of obtaining self-certification report or the certificate of Electrical Inspector. However, if there is any change in LT installation, the self-certification for the same may be obtained from the consumer as per provisions of order COMML.JDP/708.

All concerned are directed to comply with the above instructions.

By Order,

  
 (M.R. MEENA)

**ADDL.CHIEF ENGINEER (HQ)  
 JODHPUR DISCOM, JODHPUR**