

COMML.JDP-30

**JODHPUR VIDYUT VITRAN NIGAM LIMITED:JODHPUR
(DEPTT.OF COMMERCIAL OPERATIONS)**

NO:JdVVNL:SE(COMML.):JU:C.I:2001-2002:F.3

D. 86
dt. 25/4/2001**O R D E R****SUB : Simplification of procedure for release of
Domestic/Non-Domestic connection to
Multi-Storey Complexes/buildings and large
buildings Modification thereof.**


A detailed procedure was prescribed for release of Domestic/Non Domestic connections to Multi-Storey Complexes/buildings and Large buildings vide Order No.Comml-449 dt.27-11-99 and further modified/clarified vide Orders No.Comml.458, 511, 512 and 513. The matter was again reviewed in the meeting of Coordination Committee held on 27-03-2001 and following decisions were taken:

- i) For the electrification of Multi-Storey Complexes/buildings and Large buildings if the owner/builder of the complex/large building installs his own transformer then the necessity of installation of minimum capacity of 100 KVA may be waived and may allow to install distribution transformer as per requirement of their load. The capacity of the transformer shall be worked out as per the erstwhile RSEB's Order No.Comml.130.
- ii) For residential Multi-Storey Complexes/buildings and Large buildings belonging to a single person or his family members where connection is required in the name of the owner of the land for entire building and not as a tenant/occupier, if the super built up area is upto 10,000(Ten Thousand) Sq.Feet, there shall be no necessity of installation of transformer by owner of the building and their connections may be released on Jodhpur Discom's LT system provided their load desired/connected load is upto 50 KW only.

iii) For Restaurant/Hotels without any Star rating, schools, Godowns and the Dharmshalas having super built up area upto 10,000 Sq.Feet, the connection can be released on LT system if the load requirement is upto 50 KW only. However, an undertaking should be obtained from such consumer that subsequently if their connected load is found more than 50 KW, they would have to instal their own transformer otherwise their supply shall be disconnected forthwith.

iv) It is also clarified that like industrial connections, Multi-Storey Complexes/buildings and Large buildings whose designed/actual demand is more than 1500 KVA, such Multi-Storey Complexes/buildings and Large buildings will continue to be electrified only on 33KV.

This Order is issued in partial modification in the existing provisions to the extent mentioned herein above.


(O.P. SBTI)

**SUPERINTENDING ENGINEER (COMMERCIAL)
JODHPUR DISCOM: JODHPUR**

copy submitted/forwarded to the following for kind information and necessary action:

- 1) The Secretary (Energy), Govt. of Rajasthan, Jaipur.
- 2) The Zonal Chief Engineer (O&M-JDZ-BKZ), Jd.V.V.N.L., Jodhpur/Bikaner
- 3) The Chief Accounts Officer/Financial Advisor, Jodhpur Discom, Jodhpur
- 4) Superintending Engineer (O&M-CC-DC/PP&M/MM&C/M&P/BFL), Jd.V.V.N.L., Jodhpur/Pali/Churu /Barmer/ Hanumangarh/ Ganganagar/Bikaner/Jaisalmer: With the request to endorse copy of above Order amongst all the Executive Engrs./ Astd Engrs./AROs under your control.
- 5) Superintending Engineer (Power), RIICO, Jodhpur.
- 6) The Sr. Accounts Officer (O&M/MM/Audit), JdVVNL, Jodhpur/ Bikaner.
- 7) P.S. to Hon'ble Power Minister, Govt. of Raj., Jaipur.