



No JdVVNL/MD/CE(HQ)/SE(RA&C)/JU/2019-20/D 1174 Dt 30.9.19

ORDER

Sub: Installation of Dry/ Oil type Transformers in Residential/ Commercial Buildings.

In compliance of the provisions of CEA (Measures relating to safety and Electric supply) Regulation-2010), only Dry-type transformer shall be used for installation inside the residential/ commercial buildings, detailed directions were issued vide Comml JDP/488 dated 20.03 2009 as hereunder

- i If the Distribution transformer is to be installed in a residential/ commercial building in the enclosed premises at the ground floor, it shall be dry type transformer only
- ii If the Distribution transformer is to be installed in a residential/ commercial building in the basement of the building or in a floor other than ground floor of the building, it shall be dry type transformer only
- iii If however the Distribution transformer is to be installed in a residential/ commercial building at the ground floor in the open space i.e not in enclosed premises, it can be dry type or oil filled type distribution transformer

It has been observed in many cases that above directions are not being complied by the field officers/ prospective applicants strictly, it is therefore again directed that only Dry type transformers are allowed in residential/ commercial buildings except the cases where the transformer is installed in an open space at ground floor in consumer premises

All the concerned are directed to ensure the compliance of the instructions/ guidelines prescribed in Comml.JDP/488 strictly

By Order,

[Handwritten Signature]
30.9.19

(H.S.CHOUDHARY)
 ADDL.CHIEF ENGINEER (HQ)
 JODHPUR DISCOM, JODHPUR