

**JODHPUR VIDYUT VITRAN NIGAM LIMITED**

No.JdVVNL/MD/CE(HQ)/SE(RA&C)/JU/2012-13/D. 2151 Dt. 27.07.12

ORDER

Sub: Installation of Star rating transformers in Residential/ Commercial Buildings and its testing at Nigam's Central Testing Laboratory (CTL) prior to installation.

Guidelines for installation of Dry/Oil Type transformers in Residential/Commercial Buildings were prescribed vide order Comml.JDP/488 dtd 20.03.09, order Comml.JDP/491 dated 17.04.09 and order Comml.JDP/492 dtd 23.04.09.

The matter is reviewed in light of requirement prescribed by various notifications issued by Govt. of Rajasthan, Energy Deptt. and accordingly following instructions are hereby issued in partial modification of the order Comml.JDP/488 dt.20.03.09, Comml.JDP/491 dt.17.04.09 and Comml.JDP/492 dt.23.04.09:-

- i. It will be mandatory for private/other agencies to install a minimum Star Three level distribution transformers for the capacities 63, 100, 160, 200KVA from the regular suppliers/approved vendors of the Nigam, for which BEE has permitted star labeling by declaring the electrical parameters (permissible losses at 50% and 100% loading etc.). The list of latest approved vendors shall be provided by the SE (MM&C), JdVVNL, Jodhpur.
- ii. As & when BEE provides star labeling for higher capacities of distribution transformers and for dry type distribution transformers the same shall be applicable. Also if there is any change in electrical parameters made by BEE, same shall also be applicable.

All other terms and conditions of the order no. Comml.JDP/488, Comml.JDP/491 and Comml.JDP/492 will remain unchanged. It is enjoined upon all concerned to ensure strict compliance with immediate effect.

By order,

(N.M. CHOUHAN)
CHIEF ENGINEER (HQ)
JODHPUR DISCOM:JODHPUR