

**JODHPUR VIDYUT VITRAN NIGAM LIMITED**

New Power House, Industrial Area, Jodhpur-342003

No.JdVVNL/MD/CE(C&amp;P)/SE(RA&amp;C)/JU/2014-15/D. 966 Dt. 06.06.14

**ORDER**

**Sub.: Releasing of single phase electric connection to Domestic/Non Domestic consumer up to 10 KW connected load.**

In accordance with the Clause 1 (System of Supply) of TCOS-2004, the declared voltage for single phase supply is 230 volts and for three phase supply is 400 volts. In accordance with the existing provisions of Clause-2 of TCOS-2004, the connections up to 5 KW connected load are released on LT Single Phase Supply or Three Phase Supply (at the option of the consumer) and connections more than 5 KW sanctioned connected load are to be released on L.T. Three Phase Supply.

However, in accordance with the existing Clause-2 Note (iv) of TCOS-2004, the Nigam may allow supply to a consumer at a voltage level one stage higher or lower in exceptional circumstances.

Recently, some of the consumers of Domestic and Non Domestic category of rural areas have approached for allowing to release single phase connection for the connected load up to 10 KW because of non-availability of three phase supply beyond block hours in rural areas.

The matter was discussed in the 60<sup>th</sup> Discoms Coordination Forum Meeting held on 07-05-2014 and it was decided that the applicants who opt for single phase electric connection under Domestic and Non Domestic category having connected load above 5 KW and up to 10 KW may be allowed in rural areas, subject to the condition that separate single phase transformer will be installed for each connection and entire cost of 11KV Line and transformer will be borne by the applicant. The connection will be released by installing meter along with AMR arrangements in the meter box provided with transformer.

It is, therefore, enjoined upon all the field officers to adhere to above directions.

By Order,

  
(P.S.SHEKHAWAT)

**ADDL. CHIEF ENGINEER (C&P)  
JODHPUR DISCOM:JODHPUR**

Note: The order is also available on Jodhpur Discom's website [www.jdvvn.com](http://www.jdvvn.com).

Copy submitted/ forwarded to the following for information and necessary action:

- 1) The Director (Finance / Technical), Jodhpur Discom, Jodhpur.
- 2) The Zonal Chief Engineer (O&M-JDZ/ BMR/ BKZ), Jodhpur Discom, Jodhpur/ Barmer/Bikaner.
- 3) The Dy. Chief Engineer(IT-Trg & M&P / MM&C), Jodhpur Discom, Jodhpur.
- 4) The Chief Accounts Officer(B&R / IA&A / W & M), Jodhpur Discom, Jodhpur/Jaipur.
- 5) The T.A. to Chairman, Discoms, Vidhyut Bhawan, Jaipur, for kind perusal of the Hon'ble Chairman.
- 6) The T.A. to Managing Director, Jodhpur Discom/Jaipur Discom/Ajmer Discom, Jodhpur /Jaipur/ Ajmer, for kind perusal of the Hon'ble MD.
- 7) The Company Secretary, Jodhpur Discom, Jodhpur.
- 8) The Superintending Engineer (CC / DC / O&M / BFL / PP&M / TW / M&P/ MM&C/ RDPCC / Vig.), Jodhpur Discom, Jodhpur / Pali / Barmer / Sirohi / Jalore / Jaisalmer / Bikaner / Hanumangarh / Sriganganagar / Churu/ Jaipur.
- 9) The Superintending Engineer(IT & Trg.), Jodhpur Discom, Jodhpur for putting up the order on the website of Discom.
- 10) The P. S. to Hon'ble Energy Minister, Secretariat, GoR, Jaipur.
- 11) The P.S. to Secretary (Energy), Govt. of Rajasthan, Jaipur.
- 12) The TA to Electricity Ombudsman, Vidhyut Viniyamak Bhawan, Sahakar Marg, Near State Motor Garage, Jaipur, for kind perusal of Ombudsman.
- 13) The Addl. S. P. (Vigilance), Jodhpur Discom, Jodhpur. With spare copies for distribution amongst vigilance officers.
- 14) The Sr. Accounts Officer/Accounts Officer (O&M-CC / DC / Audit/ Rev), Jodhpur Discom, Jodhpur / Bikaner.
- 15) The T.A. to Addl. Chief Engineer(C&P), Jodhpur Discom, Jodhpur
- 16) The Executive Engineer (O&M/ DD/ CTL/ A-B-C-Zone/ City-I-II/ Legal/ IA / Training/ Vigilance), Jodhpur Discom,..... **for distribution amongst all the AENs/JENs/ARO under your control.**
- 17) The Public Relation Officer, Jodhpur Discom, Jodhpur.
- 18).....

  
**SUPERINTENDING ENGINEER (RA&C)**  
**JODHPUR DISCOM:JODHPUR**