

No.JdVVNL/MD/CE(C&P)/SE(RA&C)/JU/2014-15/D. 1749 Dt. 02.09.2014

ORDER


As per provision of Clause-2-“Category of Consumer and Character of Service”, of TCOS-2004 the character of service is defined as here under:-

- | | |
|--|--------------------|
| (i) Contract/actual demand upto 50KVA | LT Three Phase |
| (ii) Contract/actual demand above 50KVA
and upto 1500KVA | HT 11KV |
| (iii) Contract/actual demand above 1500KVA
and upto 5000KVA | HT 33KV |
| (iv) Contract/actual demand above 5000KVA | EHV 132KV or 220KV |

It has been observed that field officers are accepting applications for new connection or for extension in load from the existing consumers without following the above norms & thus deviating from the prescribed character of service and processing the case files for sanction by the competent authority which is violation of provision of TCOS-2004.

This practice has been viewed seriously by the higher authorities. It is therefore enjoined upon all concerned that in future the case files should only be accepted strictly for the supply voltage as prescribed in the TCOS-2004 and files having deviation in Supply Voltage as mentioned above even as per provision of clause 2(iv) of TCOS shall be accepted only after taking approval of the Competent Authority authorized for the sanction of the applied load as per D.O.P. Any lapses in this regard may attribute to the disciplinary action against defaulters. Strict Compliance of above instructions be adhered.

By Order,


 (P.S.SHEKHAWAT)
 ADDL. CHIEF ENGINEER (C&P)
 JODHPUR DISCOM:JODHPUR

Note: The order is also available on Jodhpur Discom's website www.jdvvn.com.