

**OFFICE OF THE SUPERINTENDING ENGINEER (DC),
JODHPUR DISCOM, BIKANER**
List of Fatal/Non-fatal accident occurred during financial year 2019-20

Annexure of SOM-30

Name of circle: SE (DC) JdVVNL, Bikaner

Reporting Month: MARCH 2020

S. No.	Name & Father Name	Whether Departmental Employee/Publicman	Fatal or Non-fatal	Date of Accident	Name of Sub-division	Place of Accident	Detailed reason of each Accident	Name of officer/official responsible if any for that accident	Amount of Compensation paid	Remarks
1	Sh. Panna Lal Swani S/o Mohan Lal, CCA-III	Dept Employee	Non Fatal	21.06.19	AEN (O&M) Napasar	Badnu Village	double pole structure broken	-	-	Document pending
1	Sh. Raju Ram S/o Sh.Rupa Ram Jat	Publicman	Fatal	02.03.19	AEN (R) Bkn	Hemera	while working in field	-	-	Document pending
2	Sh. Tarachand Meghwal	Publicman	Fatal	31.03.19	AEN (O&M) Kolayat	Akkasar	while changing electricity supply	-	-	Enquiry & document pending
3	Sh. Hanumana Ram S/o Utma Ram	Publicman	Fatal	24.04.19	AEN (O&M) Napasar	Mundsar	while working in field	-	Rs. 5 Lacs	-
4	Sh. Gajanand S/o Hanumana Ram	Publicman	Fatal	24.04.19	AEN (O&M) Napasar	Mundsar	while working in field	-	Rs. 5 Lacs	-
5	Sh. Chaina Ram S/o Moola Ram	Publicman	Fatal	24.04.19	AEN (O&M) Napasar	Mundsar	while working in field	-	Rs. 5 Lacs	-
6	Sh. Jagdish S/o Hardev	Publicman	Fatal	17.02.17	AEN (O&M) Kolayat	Hadla	while fusing on transformer DP	-	-	Enquiry & document pending
7	Sh. Veeru S/o purna Ram	Publicman	NonFatal	15.04.19	AEN (O&M) Bajju	80RD	11 KV line wire broken down on fencing of field	-	-	Enquiry & document
8	Sh. Chotu Ram S/o Loona Ram	Publicman	Fatal	14.05.19	AEN (O&M) loonkaransar	Chak 7 BHM	due to burst of insulator 11 KV line wire hang on tree	-	Rs. 5 Lacs	-
9	Sh. Mohan Singh S/o Kushal Singh	Publicman	Fatal	26.05.19	AEN (O&M) Jasrasar	Mondsar	without permission climb on 1 ϕ Substation	-	-	Enquiry & document pending

10	Master Sachin S/o Jamel Singh	Publicman	NonFatal	07.06.19	AEN (O&M) Khajuwala	Khajuwala	Due to contact with 11 KV	-	-	Enquiry & document pending
11	Master Aman S/o Satpal	Publicman	NonFatal	07.06.19	AEN (O&M) Khajuwala	Khajuwala	Due to contact with 11 KV	-	-	Enquiry & document pending
12	Sh. Chotu Singh S/o Gopal Singh	Publicman	Fatal	13.05.19	AEN (O&M) Jasrasar	Charkada	High voltage conductor broken due to storm on LT line	-	-	Enquiry & document pending
13	Sh. Moola Ram S/o Purkha Ram	Publicman	Fatal	20.06.19	AEN (O&M) Upani	Lkhmisar	while working on DP	-	-	Enquiry & document pending
14	Smt. Laxmi W/o Oma Ram	Publicman	Fatal	30.06.14	AEN (O&M) Nokha	Mandaliya	Electric shock	-	File closed on 17.12.19	-
15	Master Rajesh S/o Oma Ram	Publicman	Fatal	30.06.14	AEN (O&M) Nokha	Mandaliya	Electric shock	-		-
16	Km. Arti D/o Oma Ram	Publicman	Fatal	30.06.14	AEN (O&M) Nokha	Mandaliya	Electric shock	-		-
17	Sh. Bihari Lal S/o Iekh ram	Publicman	Fatal	23.07.19	AEN (O&M) Jasrasar	Jasrasar	due to electric shock through water motor	-	-	Enquiry & document pending
18	Sh. Nimba Ram S/o Hajari Ram	Publicman	Fatal	07.05.19	AEN (O&M) Jasrasar	Rohi Udsar	current flow in starter	-	-	Enquiry & document pending
19	Sh. Ram Kishan S/o Narayan Ram	Publicman	Fatal	26.07.19	AEN (O&M) Jasrasar	Rohgi Siniyala	while fusing in transformer	-	-	Enquiry & document pending
20	Sh. Swaroop Singh S/o Bhanwar Singh	Publicman	Fatal	31.07.19	AEN (O&M) Bajju	chak 4 PWM	11 KV line wire broken down	-	-	Enquiry & document pending
22	Km.Saniya D/o Imran Maniyar, age 8 yrs	Publicman	Fatal	19.08.19	AEN (O&M-I) SDGH	ward no. 16	contact with 11 KV lines	-	-	Enquiry & document pending
23	Master Ram Kumar S/o Sita Ram, age 10 yrs	Publicman	NonFatal	30.07.19	AEN (R) Bikaner	lalaras	fall of Conductor due to fault in 11 KV insulator	-	-	Enquiry & document pending
24	Sh. Harish Mehra	Publicman	Fatal	23.08.19	AEN (O&M) Bajju	Bajju	current flow in domestic cooler	-	-	Enquiry & document pending
25	Sh. Sushil Kumar S/o Pawan Brahmin	Publicman	Fatal	24.08.19	AEN (O&M) Khajuwala	2 KLD	which adjusting 11 KV jumper without permission	-	-	Enquiry & document pending

26	Sh. Lalchand S/o Shivji Ram	Publicman	Fatal	05.09.19	AEN (O&M) Kolayat	Rohi Jhajhu	current flow in transformer	-	-	Enquiry & document pending
27	Sh. Jaipal Singh S/o Sadul Singh	Publicman	Fatal	07.10.19	AEN (O&M) Kolayat	Rohi Bhelu	current flow in fencing	-	-	Enquiry & document pending
28	Smt. Parvati Devi W/o Omprakesh	Publicman	NonFatal	19.09.19	AEN (O&M) Bajju	chak 3 DOBB	HT line current flow in LT line	-	-	Enquiry & document pending
29	Sh. Himmat Nath S/o prabhu nath sidh	Publicman	Fatal	16.02.19	AEN (O&M-I) SDGH	Benisar	due to direct contact with 11 KV live line voltage	-	-	Enquiry & document pending
30	Smt Anni Devi W/o Karna Ram	Publicman	Fatal	01.08.19	AEN (O&M) Bajju	girajsar	due to blast in solar battery	-	-	Enquiry & document pending
31	Sh. Mangi Lal S/o Panna Lal	Publicman	Fatal	06.11.19	AEN (O&M) Jasrasar	Nokha	current flow in awich board	-	-	Enquiry & document pending
32	Sh. Gopal Singh S/o Dhanne Singh	Publicman	Fatal	08.10.19	AEN (O&M) Bajju	4 PBM	11 KV current flow in LT line	-	-	Enquiry & document pending
33	Sh. Baldev S/o Swai Singh	Publicman	Fatal	25.05.19	AEN (O&M) Kolayat	Madh Road	11 KV line passing through tree baldev climb on tree	-	-	Enquiry & document pending
34	Sh. Panna Ram S/o Balu ram	Publicman	Fatal	26.09.19	AEN (O&M-II) SDGH	Dheerdesar Chotiyar	contact with 11 KV lines	-	-	Enquiry & document pending
35	Sh. Kishan Nayak S/o Pura Ram	Publicman	Fatal	22.07.19	AEN (O&M) LKSR	Karnisar	while unloading truck	-	-	Enquiry & document pending
36	Sh. Ishar Ram S/o Brij Lal	Publicman	Fatal	26.09.19	AEN (O&M) Bajju	Chak 3 CDY	broken 11 KV lines	-	-	Enquiry & document pending
37	Sh. Ved Prakesh S/o Mani Ram	Publicman	Fatal	13.08.19	AEN (O&M) CHRGH	Chak 9 SLD	LT service line touched with fuse of 11 KV	-	-	Enquiry & document pending
38	Sh. Mani Ram S/o Aadram	Publicman	Fatal	25.12.19	AEN (O&M) LKSR	Amarpura	while working in field	-	-	Enquiry & document pending

39	Sh. Rajesh S/o Sukar	Publicman	Fatal	14.01.20	AEN (O&M) Kolayat	Chak Muljayan	while placing 11 KV phuse	-	-	Enquiry & document pending
40	Sh. Likhma Ram S/o Jagdish Ram	Publicman	NonFatal	14.01.20	AEN (O&M) LKSR	Sekhsar	while clearing 11 KV Fault without permission	-	-	Enquiry & document pending
41	Sh. Chaggan Lal S/o Daulat Ram	Publicman	Fatal	03.19, khumba	AEN (O&M) Nokha	khumbasar	while changing lines			
42	Sh. Bhagwana Ram S/o Shiv Lal	Publicman	Fatal	10.19, Godu B	AEN (O&M) Bajju	Godu Bajju	current flow in stay wire			
43	Sh. Rupa Ram S/o Ashu Ram	Publicman	Fatal	2.2020, Dhing	AEN (O&M) Nokha	Dhingasari	Electric shock while changing water pipe in aggriculture filed			
44	Km. Mamta D/o Bhagwana Ram	Publicman	Fatal	3.2020, 40 DOD	AEN (O&M) Khajuwala	40 DODD	contact with broken 11 KV line wire broken			
45	Sh. Ramniwas S/o Dhanna Ram	Publicman	Fatal	3.2020, 40 DOD	AEN (O&M) Khajuwala	40 DODD	contact with broken 11 KV line wire broken			

**OFFICE OF THE SUPERINTENDING ENGINEER (O&M)
JODHPUR VIDYUT VITRAN NIGAM LTD. CHURU**

List of Fatal/Non-fatal accident occurred during financial year 2019-20

Annexure of SOM-30

Name of Circle: CHURU

Reporting Month: MARCH

S. No.	Name & Father Name	Whether Departmental Employee /Publicman	Fatal or Non-fatal	Date of Accident	Name of Sub-division	Place of Accident	Detailed Reason of each Accident	Name of officer/official responsible if any for that accident	Amount of Compensation paid	Remarks
1	Kumari Aaina D/o Sh. Pemaram Bhat	Publicman	Fatal	14.05.19	(Rural) Churu	Dhodhaliya, churu	current flow in sopt wire of service line		5 Lac	
2	Sh. Rampal S/o Sh Birju Ram	Publicman	Fatal	15.05.19	(Rural) Churu	chhajusar	high volatage flow in domestic supply		5 Lac	
3	Raju Singh S/o Balu Singh	Publicman	Fatal	25.05.19	Rural, Rajaldesar	Rajaldesar, Churu	During Cutting of tree contact with live Line		Nigam Not responsible	
4	S/o Akharam, Ramsisar Bhedwaliya, Tehsil sardarshahar	Publicman	Fatal	06.06.19	(O&M), Bhadsar	Ramsisar, Bhedwaliya	During agriculture work			
5	Rakesh S/o Mangilal Saran, Parrewda	Publicman	Fatal	22.11.19	(O&M), Bidasar	Parrewda	During un authorised line luping work			
6	Raju Ram S/o Laluram Pilaniya Vill- Bhompura, Tehsil Bidasar	Publicman	Fatal	27.07.19	(O&M), Bidasar	Bhompura	During operating water booster			
7	Sh. Praveen Kumar Dhaka S/o Mahaveer Singh	Nigam Emp	Non- Fatal	16.08.19	(Rural) Churu	Bas Dhakan Churu	Due to air current		under process	
8	Sh Pratap Singh S/o Kalu Singh H-I	Nigam Emp	Non- Fatal	16.09.19	(O&M) Sujangarh	Near Shankar Aara Machine	during working for line amintainance work		under process	
9	Sh. Mohar Singh, Village Nehrana	Publicman	Fatal	05.01.20	(O&M) Sahwa	Sardarsahar Road	Unawareness of truck driver			

**OFFICE OF THE SUPERINTENDING ENGINEER(O&M),
JODHPUR VIDYUT VITRAN NIGAM LTD. HMH**

List of Fatal/Non-fatal accident occurred during financial year 2019-20

Reporting Month: MARCH

Name of Circle: HMH

SOM 30 Annex

S. No.	Name & Father Name	Whether Departmental Employee /Publicman	Fatal or Non-fatal	Date of Accident	Name of Sub-division	Place of Accident	Detailed Reason of each Accident	Name of officer/official responsible if any for that accident	Amount of Compensation paid	Remarks
1	श्री संदीप / पृथ्वीराज टैक्नीकल हैल्पर	निगम कार्मिक	अघातक	04/05/19	(वि.) पीलीबंगा	8 एल के एस, थिराजवाला, लखासर	ट्रांसफार्मर फाल्ट ठीक करते वक्त 11 केवी से करंट लगने	—	—	Enquiry pending with XEN,HMH
2	श्री अकरम / श्री गफ्फूर खान	आमजन	घातक	18/04/19	(वि.) नोहर	दीपलाना	टेन्ट के टावर पर चढ़कर टेन्ट हटाते हुए 11 केवी लाईन के सम्पर्क में आने से	—	500000	D. 165/ 28.06.19
3	श्री रोहित सिंह / श्री सिकंदर सिंह	आमजन	घातक	20/04/19	(वि.) हनुमानगढ़. टा0	वार्ड न. 28	छत से नीचे गाड़ी देखते वक्त 11 केवी लाईन के सम्पर्क में आने से	—	—	Comp. denied by Committee D.303 Dt. 23.08.19
4	श्री सुभाष / श्री जयचंद	आमजन	घातक	18/04/19	(वि.) रावतसर	3 सी एल डी खोदान	बस के ऊपर खड़ा होने से 11 केवी लाईन के सम्पर्क में आने से	—	500000	D. 166/ 28.06.19

5	श्री मनीष / श्री हंस राज	आमजन	अघात क	28०04०19	(वि.) गोलूवाला	चक 15 जे डी डब्ल्यू	11 कवा लाइन क पोल पर चढ़ कर ऊपर बैठे कबूतर को पकड़ते समय संपर्क में आने से।	—	—	Enquiry pending with XEN,HMH
6	श्री सुखमंदर सिंह / हरदेव सिंह	आमजन	घातक	24०09०18	(वि.) हनुमानगढ़.	2 केएनजी, मक्कासर	मोटर चलाते समय स्टार्टर से करंट आने पर	—	—	Comp. denied by Committee D.294 Dt. 21.08.19
7	श्री केवलराम / श्री जिसुखराम	आमजन	घातक	27०06०19	(वि.) पल्लू	फोगला की रोही	टूट हुए 11 कवा लाईन को उठाते समय करंट आने	—	500000	D. 535/ 29.11.19
8	श्री प्रमोद कुमार / धर्मपाल	निगम कार्मिक	अघात क	31०08०19	(वि.), भादरा	33 कवा सब-स्टेशन, भादरा	11 केवी का फ्यूज लगाते समय।	—	—	No permanent Disability
9	श्री शाहरूख खान / यासीन खान	आमजन	अघात क	01०09०19	(वि.), नोहर	नोहर	गुजर रही 11 केवी लाईन के सम्पर्क में आने से।	—	—	Enquiry pending with XEN, NHR
10	श्री अमरजीत / बुधराम	आमजन	घातक	10०10०19	(वि.), रावतसर	रावतसर	मीटर से निकलने वाले वायर में कट होने से करंट की चपेट में आने से।	—	—	Comp. denied by Committee D.501 Dt. 13.11.19
11	श्री मोहनलाल / लालचन्द	आमजन	घातक	26०10०19	(वि.), रावतसर	9 आर पी, रावतसर	लकाडिया स मरा ट्रेक्टर ट्राली निकालते समय 11 केवी लाईन के	—	500000	D. 503/ 13.11.19
12	श्री विकास / सैदाराम	आमजन	घातक	19०11०19	(वि.), रावतसर	2 एच एल एम	लकाडियों से भरी ट्रेक्टर ट्राली निकालते समय 11	—	500000	D. 677/ 28.01.2020
13	श्री सतीश / मनीराम जाट	आमजन	घातक	01०12०19	(ग्र.), भादरा	भिरानी	ट्रेक्टर ट्राली की बिड 11 केवी लाईन के सम्पर्क में आने	—	500000	D. 683/ 31.01.2020

14	श्री मनोज कुमार/भूरा सिंह, हेल्पर प्रथम	निगम कार्मिक	अघात क	03०01०20	(वि.) संगरिया	5 एफ.टी.पी., कुलचासर	11 केवी लाईन के सम्पर्क में आने से	—	—	No permanent Disability
15	श्री जगदेव सिंह, श्री तरसेम सिंह, श्री अजायब सिंह, श्री लखवीर सिंह	आमजन	अघात क	11०01०20	(वि.) गोलूवाला	चक 16 जे. आर. के.	11 केवी लाईन के सम्पर्क में आने से।	—	—	Enquiry pending with XEN,Hanuman garh
16	श्री विनोद/सोहनलाल	आमजन	घातक	06०02०20	(वि.) पल्लू	अर्जुनसर रोड	ट्राली से नीचे उतरते वक्त 11 केवी लाईन के सम्पर्क में आने से।	—	—	Comp. denied by Committee D.724 Dt. 08.02.20
17	श्री सुरजीत सिंह/श्री जरनेल सिंह	आमजन	अघात क	09०03०20	(वि.) हनुमानगढ.	लालाजी बालाजी मार्केट				Enquiry pending with XEN,Hanuman garh
18	श्री राजू सिंह/श्री जीत सिंह	आमजन	अघात क	16०03०20	(ग्रा.) हनुमानगढ.	वार्ड नं. 4, सुरेवाला	छेड़छाड. करते समय झटका लगने से।			Enquiry pending with XEN,Hanuman garh

**OFFICE OF THE SUPERINTENDING ENGINEER(O&M),
JODHPUR VIDYUT VITRAN NIGAM LTD. SRI GANGANAGAR**

List of Fatal/Non-fatal accident occurred during financial year 2019-20

Annexure of SOM-30

Name of Circle		Sri Ganganagar					Reporting Month: MARCH			
S. No.	Name & Father Name	Whether Departmental Employee /Publicman	Fatal or Non-fatal	Date of Accident	Name of Sub-division	Place of Accident	Detailed Reason of each Accident	Name of officer/official responsible if any for that accident	Amount of Compensation paid	Remarks
1	Sh. Rampratap	T.H.	Non-fatal	12 ⁰⁴ 2019	R SOG	6 SGM	विद्युत तन्त्र पर कार्य करते समय विद्युत करन्ट लगने से दुर्घटना घटित हुई।	जांच अधिकारी की जांच रिपोर्ट लम्बित है।
2	Sh. Omprakash	publicman	Non-fatal	10 ⁰⁴ 2019	Gajsinghpur	Gajsinghpur	बिना निगम को सूचना दिये विद्युत तन्त्र पर कार्य करते समय करन्ट लगने से दुर्घटना घटित हुई।	जांच अधिकारी की जांच रिपोर्ट लम्बित है।
3	Sh. Emichand	publicman	Non-fatal	18 ⁰⁴ 2019	Anoopgarh	Anoopgarh	स्पोर्ट वायर में विद्युत करन्ट आने के कारण दुर्घटना घटित हुई।	जांच अधिकारी की जांच रिपोर्ट लम्बित है।
4	Sh. Naresh Kumar	T.H.	Fatal	27 ⁰⁶ 2019	R SGNR	Vill. Fatuhi	सहा.अभि. की प्रा. रिपोर्ट के अनुसार डीओ फयूज लगाते समय 11 केवी का करन्ट लगने से दुर्घटना घटित हुई।	जांच अधिकारी की जांच रिपोर्ट लम्बित है।
5	Sh. Sushil	publicman	Non-fatal	15 ⁰⁷ 2019	C-II SGNR	Purani Abadi SGNR	अनुसार छत पर खेलते समय 11 केवी का करन्ट लगने से दुर्घटना घटित हुई।	जांच अधिकारी की जांच रिपोर्ट लम्बित है।
6	Sh. Bhavani Gir	T.H.	Non-fatal	18 ⁰⁹ 2019	Jaitsar	3 J.S.D jaitsar	सहा.अभि. की प्रा. रिपोर्ट के अनुसार विद्युत कार्य में रखरखाव के कारण दुर्घटना घटित हुई।	जांच अधिकारी की जांच रिपोर्ट लम्बित है।

7	Sh. Shailender Singh	publicman	Non-fatal	08 th 10 th 2019	R SOG	Vill. 38 PBN	सहा.अभि. की प्रा. रिपोर्ट के अनुसार घग्घर नदी में अत्यधिक जल प्रवाह होने के कारण विद्युत पोल टेढा हो गया जिससे दुर्घटना घटित हुई।	जांच अधिकारी की जांच रिपोर्ट लम्बित है।
8	Sh. Devi Lal	publicman	fatal	18 th 12 th 2019	Padampur	Vill. 84LNP	सहा.अभि. की प्रा. रिपोर्ट के अनुसार 11 केवी का करन्ट लगने से दुर्घटना घटित हुई।	जांच अधिकारी की जांच रिपोर्ट लम्बित है।
9	Sh. OM Parkash	publicman	fatal	20 th 12 th 2019	SriKaranpur	Vill. Chak 12 O	सहा.अभि. की प्रा. रिपोर्ट के अनुसार छत पर खेलते समय 33 केवी लाईन के नीचे ट्राली में तुड़ी डालते समय दुर्घटना घटित हुई।	जांच अधिकारी की जांच रिपोर्ट लम्बित है।
9	Sh. Raju Ram Bawri	publicman	fatal	31 st 01 st 2020	SriKaranpur	Vill. Chak 40 Laksiya	सहा.अभि. की प्रा. रिपोर्ट के अनुसार विवाह समारोह में टन्ट लगाते समय 11 केवी लाईन के सम्पर्क में आने से दुर्घटना घटित हुई।	जांच अधिकारी की जांच रिपोर्ट लम्बित है।

List of Fatal/Non-fatal accident occurred during financial year 2019-20

Annexure of SOM-30

Name of Circle- Barmer

S. No.	Name & Father Name	Whether Departmental Employee/Publicman	Fatal or Non-fatal	Date of Accident	Name of Sub-division	Place of Accident	Detailed Reason of each Accident	Amount of Compensation paid	Remarks
1	Poonma Ram /Narna Ram	Public Man	Fatal	04.04.2019	AEN(CSD-II), Barmer	Rico	निर्माणाधीन मकान पर कार्य करते समय करंट लगने से	Not Entitle	
2	Chetan Ram /Dama Ram	Contractor Person	N/F Fatal	16.04.2019 18.04.2019	AEN(O&M) Sindhari	Sarnu	बिना सप्लाई बन्द कर फ्युज बाधते समय करंट लगने से	Contractor Person	मुआवजे की जिम्मेदारी संबंधित ठेकेदार की बनती है एवं इस कार्यालय के पत्रांक 217 दिनांक 15.07.2019 द्वारा संबंधित ठेकेदार को मुआवजे हेतु लिखा गया है।
3	Ibrahim /Aki Khan	Public Man	N/F Fatal	25.04.2019	AEN(O&M), Pachapadra	Sabhara	Electroluction	Not Entitle	
4	Hina /Ghewa Ram	Public Man	N/F	12.05.2019	AEN(O&M), Padru	Padru	Electroluction	Not Entitle	
5	Surendra Kumar/Ugra ram	Public Man	Fatal	12/05/2019	AEN(O&M), Gida	Nimbaniyo ki dhani	Electroluction	Not Entitle	
6	Punu /Mukim	Public Man	Fatal	18.05.2019	AEN(O&M), Sedwa	Sihaniya	भारत माला प्रोजेक्ट में पानी डालते समय करंट लगने से	Not Entitle	
7	Khiya ram/Pokar ram	Public Man	N/F	18.05.2019	AEN(O&M), Gida	pareu	Electroluction	Not Entitle	
8	Bhom singh/ Arjun Singh	Public Man	Fatal	19/05/2019	AEN(O&M), Gida	Jajwa	Electroluction	Not Entitle	
9	Chel Nath /Rup Nath	Public Man	Fatal	20.05.2019	AEN(O&M), Samdari	Adiyari Bhakhari	स्टे वायर में करंट आने से	Order No. 281 Dt. 05/08/2019 500000/-	
10	Deepa ram	Public Man	Fatal	30/05/2019	AEN(O&M), Baytu	Baytu	Electroluction	Not Entitle	
11	Maya Devi/Shravan Kumar	Public Man	Fatal	02/06/2019	AEN(Rural), Barmer	Sanawada	Electroluction	Not Entitle	

12	1.Tugi Devi/ Chena ram 2.Bhagaram/ Bharuram 3. Mula ram/ chena ram 4. Kamala / chena ram	Public Man	1 Fatal 3 N/F	11/06/2019	AEN(O&M), Chohtan	Shriramwala	Electroluction	Order No. 232 Dt. 19.07.2019 500000/-	1. Case of Tugi Devi is under Fatal Accident and amount is paid off 2. Kamla is not entitle for compentation 3. Mula ram & Bhagaram Admitted in the hospital Case will be clarify after receiving diability certificate if any.
13	Chuna ram/Achlaram	Public Man	Fatal	11/06/2019	AEN(O&M), Gida	Malwa Charnan	Electroluction	Order No. 280 Dt. 05/08/2019 500000/-	
14	Bhiya ram/Deva ram	Public Man	Fatal	12/06/2019	AEN(O&M), Gudamalani	Gadevi	Electroluction	Order No. 5457 Dt. 16.10.2019 500000/-	
15	Hemaram/ Magnaram	Public Man	Fatal	18/06/2019	AEN(CSD-II), Barmer	Rohili	Electroluction	Not Entitle	
16	Shyam Lal/Prabhu Lal	Department Employee	N/F	24/06/2019	AEN(O&M), Balotra	Balotra	Electroluction	Not Entitle	No Disability
17	Tan Singh/ Agar Singh	Public Man	Fatal	28/06/2019	AEN(O&M), Chohtan	Dudhwa	Electroluction	Order No. 349 Dt. 27/08/2019 500000/-	
18	Mathu singh/ Sambhu Singh	Public Man	Fatal	11/07/2019	AEN(O&M), Siwana	Meli	Electroluction	Not Entitle	
19	Joga Ram/Dola Ram	Public Man	Fatal	13/07/2019	AEN(O&M), Baytu	baytu	Electroluction	Not Entitle	
20	Purkha ram/ Hema ram	Public Man	Fatal	22/07/2019	AEN(O&M), Sedwa	Bhakhasar	Electroluction	Order No. 515 Dt. 30/10/2019 500000/-	
21	Mohit / Chelaram	Public Man	Fatal	20/07/2019	AEN(O&M), Pachpadra	Ghadoi charnan	Electroluction	Pending	Essential documents like death certificate,F.I.R yet not received
22	Bhaga ram/ Bhimaram	Department Employee	N/F	25/07/2019	AEN(O&M), Chohtan	Sobhala	Electroluction	Medical disability certificate yet not received	

23	Chena Ram/ Jala Ram	Public Man	N/F	29/07/2019	AEN(CSD-II), Barmer	Chawa , Sarnu	Electroluction	Not Entitle	
24	Geeta Devi/ Krishan Kumar	Public Man	Fatal	10/08/2019	AEN(O&M), Gudamalani	Ishwarpura, Banta	Electroluction	Not Entitle	
25	Praveen/Amba Ram	Public Man	Fatal	11/08/2019	AEN(O&M), Chohtan	AKODA	Electroluction	Enquiry pending	
26	Mularam/Achlaram	Public Man	Fatal	18/08/2019	AEN(Rural), Barmer	Ude ka Tala	Electroluction	Not Entitle	
27	Dinesh Kumar/Lunkaran	Public Man	Fatal	02/09/2019	AEN(O&M), Sheo	Gunga	Electroluction	Order No. 614 Dt. 30/12/2019 500000/-	
28	1. Shayam Kumar/Pemaram 2.Dharmaram/ Pemaram	Public Man	1.Fatal 2.Non fatal	13/09/2019	AEN(O&M), Dhorimanna	Badha	Electroluction	Not Entitle	
29	Magaram /Hukmaram	Public Man	1.Fatal	23/09/2019	AEN(O&M), Bhiyad	Ramdev Nagar, Mokhab	Electroluction	Order No. 774 Dt. 17/03/2020 500000/-	
30	Tikam chand / Punma Ram	Public Man	1.Fatal	23/09/2019	AEN(O&M), Gudamalani	Ramji ki Gol	Electroluction	Not Entitle	
31	Prakash Choudhary/Vagta Ram	Public Man	1.Fatal	13/10/2019	AEN(CSD-I), Barmer	Hapo Ki Dhani	Electroluction	Enquiry pending	
32	Laxman Ram/ Mukna Ram	Department Employee	N/F	31/10/2019	AEN(R), Barmer	Undhakha	Electroluction	Enquiry pending	
33	Taga Ram/Budha Ram	Department Employee	Fatal	09/11/2019	AEN(CSD-II), Barmer	Bhadhkha	Electroluction	pending	

OFFICE OF THE SUPERINTENDING ENGINEER(O&M),

JODHPUR VIDYUT VITRAN NIGAM LTD. JAISALMER

Annexure of SOM-30

List of Fatal/Non-fatal accident occurred during financial year 2019-20

Name of Circle

Reporting Month

Mar-20

S. No.	Name & Father Name	Whether Departmental Employee /Publicman	Fatal or Non-fatal	Date of Accident	Name of Sub-division	Place of Accident	Detailed Reason of each Accident	Name of officer /official responsible if any for that accident	Amount of Compensation paid	Remarks
1	Sh. Rajesh meena	Deptt. Employee	Fatal	21.03.2019 DOD-03.05.2019	AEN(O&M) Pokaran	33/11 kv s/s at Naniyanai	Due to Electrocuton By 11KV yard	Nil	Rs.861120	Enquiry completed/ compensation Sanctioned vide 00.2484,dt 21.08.19
2	Sh. Rajendra Kumar	Deptt. Employee	Non-Fatal	25.06.2019	AEN(O&M) Fatehgarh	33/11 kv GSS at Chhoddiya	Due to Electrocuton by 11 kv line	nil		Under Medical treatment/ No disability certificate submitted
3	Smt. Sohani Devi	Public Man	Fatal	15.06.19	AEN(O&M) Nachana	12 NUD Madasar	Due to Electrocuton by 11 kv Feeder Jaluwala	Nil	Rs. 500000	Enquiry completed/ compensation Sanctioned vide 00.4723,dt 04.12.19
4	Sh. Gopal Ram	Public Man	Fatal	26.06.19	AEN(O&M) Nachana	11 KV Karnewala Feeder	Due to Electrocuton by 11 kv Feeder Karnewala	Nil	Rs. 500000	Enquiry completed/ compensation Sanctioned vide 00.4722,dt 04.12.19
5	Sh. Harchand	Public Man	Fatal	20.07	AEN(O&M) Jaisalmer	vijay laxmi w/o Ravindra's tubewell	Due to Electrocuton at Tubewell	Nil	Rs. 500000	Enquiry completed/ compensation Sanctioned vide 00.5027,dt 19.12.19
6	Sh. Ajaypal Singh	Public Man	Non-Fatal	29.07.19	AEN(O&M) Bhaniyana	Vill. Dantal	Due to Electrocuton by Low Volatage (240 Volt)	Nil		Enquiry completed, No dissability certificate submitted yet
7	Sh. Khet Singh	Public Man	Fatal	31.07.19	AEN(rural) Jaisalmer	Approx 2km before Dhaneli Vill.	Due to Electrocuton by 11 kv	Nil		postmortem report not submitted yet
8	Sh. Nepal Singh	Public Man	Non-Fatal	31.07.19	AEN(rural) Jaisalmer	Approx 2km before Dhaneli Vill.	Due to Electrocuton by 11 kv	Nil		Enquiry completed, No dissability certificate submitted
9	Sh. Chagna Ram	Public Man	Non-Fatal	14.08.19	AEN(O&M) Chandhan	11 kv Feeder Sodhakor	Due to Electrocuton by 11 kv	Sandeep Kumar (TH), Dhara Singh (TH)		No disability certificate submitted
10	Sh. Chima Ram	Public Man	Fatal	15.09.19	AEN (Rural) Jaisalmer	4ATM ASHUTAR Road Post bandha	Due to Electrocuton by 33/11 kv	Nil	Rs. 500000	Enquiry completed/ compensation Sanctioned vide 00.4702,dt 04.12.19
11	Sh. Mohan Singh	Deptt. Employee CCA-III	Fatal	20.10.19	AEN(O&M) Chandhan	badoda village	Due to repairing work at LT line pole broken	Nil	639200	Enquiry completed/ compensation Sanctioned vide 00.5985,dt 14.02.20
12	Sh. Jivan Ram	Public Man	Fatal	18.11.19	AEN(O&M) Nachana	Askandra village Nachana	Due to Electrocuton by 11 kv Feeder Askandra	Nil		Enquiry completed/ under process/ certified document not submitted yet
13	Sh. Malak kha	Public Man	Fatal	03.11.19	AEN(O&M) Bhaniyana	Rajmathai village	Due to Electrocuton by LT line	Nil		under process/certified document not submitted yet

Annexure of SOM-30

Name of Circle:- JALORE

Month March-2020

List of Fatal/Non-fatal accident occurred during financial year 2019-20

S.N	NAME	P/S	F/NF	DATE OF ACCIDENT	SUB DIVISION	PLACE OF ACCIDENT	REASON	DEFAULTER	COMP. OF ORDER NO.	REMARK
1	Sh.Pukhraj S/o Babulal	Public Man	Fatal	08.04.2019	Chitalwana	Meghvalo ki dhani, siwada	when he was starting the motor starter at his agriculture well Due to fault in motor starter,he came into influence of current and due to electric shock he died	----		Nigam not responsible
2	Sh. Shrawan Kumar S/o Posaram	Public Man	Non-Fatal	05.04.2019	Bagra	Bhetala	When he was climbed on the tree he came into influence of 11 kv line which was going nearby tree and got electrical shock	----		Nigam not responsible
3	Sh. Prahlad S/o Punaram	Public Man	Fatal	01.05.2019	Chitalwana	Chitalwana	due to self careless and unauthorised cable connection		Nigam not responsible
4	Smt. Banni Devi w/o Prahlad	Public Man	Fatal	01.05.2019	Chitalwana	Chitalwana	due to self careless and unauthorised cable connection		Nigam not responsible
5	sh. Jitendar kumar S/o sh. Nanji ram	Public Man	Fatal	08.05.2019	Raniwara	Jakhad	at time of changing shower pipe the flow of water touched 11 kv line	Compensation of 5 lac sanctioned via letter no. 3718/30.08.2019	
6	Sh. Bhura Ram s/o Chela Ram	Public Man	Non-Fatal	19/06/19	Jalore	Godan	Iron rodd touched 11 kv line by child on roof			No Disability and Nigam not responsible
7	Sh. Madrupa Ram S/o Vardharam	Public Man (Contract labour)	Fatal	26/06/2019	Jeewana	Jalampura	VCB not closed and maintenance of line without cutting GO of feeder			Compensation paid by contractor
8	SH. KANA RAM S/O CHHOGA JI	Public Man	Fatal	14.07.2019	JASWANTPU	RAJPURA	due to 11 kv wire breaks and fall upon victim		Compensation of 5 lac sanctioned via letter no. 2777/22.07.2019	
9	SH. NIMBU DEVI S/O RUDA JI	Public Man	Fatal	14.07.2019	JASWANTPU	RAJPURA	due to 11 kv wire breaks and fall upon victim		Compensation of 5 lac sanctioned via letter no. 2779/22.07.2019	
10	SH. MAFARAM S/O RUDA JI	Public Man	Fatal	14.07.2019	JASWANTPU	RAJPURA	due to 11 kv wire breaks and fall upon victim		Compensation of 5 lac sanctioned via letter no. 2778/22.07.2019	
11	SH. RAWA RAM S/O SONARAM	Public Man	Fatal	19-05-2019	VASAN DEVI	SANKAD	DUE TO STAY WIRE REMOVING FROM FIELD WITHOUT ANY INFORMATION TO DEPT			Nigam not responsible
12	SH. PANKU DEVI W/O OBARAM	Public Man	Fatal	12.08.2019	JEEWANA	JEEWANA	when she was starting the motor starter at her agriculture well Due to fault in motor starter,he came into influence of current and due to electric shock she died		Compensation of 5 lac sanctioned via letter no. 6594/31.12.2019	
13	SH. LIKHAMARAM S/O KUMBHARAM	Public Man	Fatal	03.05.2019	DHUMBRIYA	RANGALA	at time of changing shower pipe the flow of water touched 11 kv line			Inquiry Pending (XEN- Sanchore)
14	SH. JABRARAM S/O BHOMARAM	Public Man	Fatal	2.10.2019	SAYLA	VALERA	due to 11 kv wire breaks and fall upon victim		Compensation of 5 lac sanctioned via letter no. 6595/31.12.2019	
15	Sh. Deepa ram S/O Hati Ram	Public Man	Fatal	15.02.2020	JEEWANA	Bawatara	Death due to current during drying clothes on wire			Nigam not responsible
16	Smt Manju Devi W/O Deepa ram	Public Man	Fatal	15.02.2020	JEEWANA	Bawatara	Death due to current during drying clothes on wire			Nigam not responsible
17	Sh. Bhaga ram S/O Dhuka Ji Bheel	Public Man	Non Fatal	19.02.2020	JEEWANA	Mokni kheda	at time of changing shower pipe the flow of water touched 11 kv line			No Disability and Nigam not responsible
18	Sh. Sadlaram S/o Jujaji	Public Man	Fatal	25.02.2020	Jalore	Bhawrani	at time of tree cutting came into influence of 11 kv line			Inquiry Pending (XEN- Sayla)
19	Sh Peer singh S/o Bhopal singh	Public Man	Fatal	19.02.2020	Jalore	Sakarna	Due to touching of pipe with transformer			Inquiry Pending (XEN- Sayla)
20	Sh. Bhana Ram Meghwal SO Sakaram	Public Man	Fatal	24/03/2020	Jeewana	Aakwa	At the time of working in field, DARANTI touched with 11 kv line			Inquiry Pending (XEN- Jalore)

JODHPUR VIDHYUT VITRAN NIGAM LTD.
CITY CIRCLE, JODHPUR

Annexure of SOM-30

List of Fatal/Non-Fatal accident occurred during financial year 2019-20

Reporting Month :- April 2020'

S.No.	Name & Father Name	Whether Departmental Employee/Publicman	Fatal or Non-Fatal	Date of Accident	Date of Sub-division	Place of Accident	Detailed Reason of each Accident	Name of Officer/Official responsible if any for that accident	Amount of Compensation paid(In Lacs)		Remarks
1	2	3	4	5	6	7	8	9	10		11
1	Sunar Ram	Publicman	Fatal	17.05.2019	AEN C-II	Rai ka Bagh Bus Stand	Due to probable current leakage in the metallic pipe support of the tin shed of shop in the control of owner	-	-	-	-
2	Mukesh	Publicman	Fatal	10.06.2019	Aen B-IV	Basani Industrial Area Gali no. 6	due to touch with 11 KV under ground cable while working	No officials held defaulter	-	-	-
3	Lalit	Publicman	Fatal	15.09.2019	Aen C-I	Jalechi Jhalra, Jodhpur	Fallen from Balcony and probably contact with live line	-	-	-	-
4	Pathani Devi	Publicman	Fatal	13.01.2020	Aen A-I	Near Rajdaan Mansion	Due to touch with G.I. wire L.T.Line	-	-	-	-
5	Unknown	Publicman	Fatal	27.03.2020	Aen B-III	Near Bombay Motor Circle	Due to touch with HRC box in LT Panal Box	-	-	-	-

List of Fatal/Non-Fatal Electrical Accident of Nigam's employee and publicman occurred during 2019-20

Name of Circle Sirohi

Month of MAR-2020

Reporting Month- APRIL-20

S. No.	Name & Father Name	Whether Departmental Employee/Publicman	Fatal/Non Fatal	Date of Accident	Name of Sub-division	Place of Accident	Detailed Reason of each Accident	Name of officer/official responsible if any for that accident	Amount of Compensation paid	Remarks
1	सुश्री अनिता पुत्री श्री जैसल सिंह	Public woman	Non Fatal	08.04.19	आबूरोड (ग्रामीण)	वासड़ा मावल	तेज गर्मी के कारण सिंगल फेज ट्रांसफार्मर अर्थिंग में नमी कम हो गई थी जिस कारण अर्थिंग में विद्युत प्रवाह हुआ उक्त आमजन अर्थिंग के सम्पर्क में आ गई तथा करंट लगा।			Enquiry pending
2	श्री गोविन्द कुमार समाजी	Public woman	Fatal	22.04.19	पिण्डवाडा	पिण्डवाडा	घर पर कलर का कार्य करते हुये छत के किनारे से गुजर रही 11 केवी लाईन के सम्पर्क में आने से उक्त दुर्घटना घटी।			उक्त दुर्घटना में निगम की भूमिका नहीं होने के कारण उक्त प्रकरण में मुआवजा स्वीकृत नहीं किया गया।
3	श्री धन्नाराम मेगाजी	H-I	Non Fatal	26.04.19	कालन्दी	कालन्दी	11 केवी फीडर पर फ्यूज बांधते समय अन्य फीडर के सम्पर्क में आने से उक्त दुर्घटना घटी।			पारिरीक अपंगता प्रमाण पत्र प्रस्तुत नहीं किया गया।
4	श्री कमला पुत्र श्री गला गरासिया	Public woman	Fatal	19.05.19	आबूरोड (ग्रामीण)	आबूरोड	मोटर स्टार्टर में विद्युत प्रवाह होने से उक्त दुर्घटना घटी।			उक्त दुर्घटना में निगम की भूमिका नहीं होने के कारण उक्त प्रकरण में मुआवजा स्वीकृत नहीं किया गया।
5	श्री बाबूराम पुत्र श्री अलू जी	Public woman	Fatal	06.05.19	जावाल	जावाल	कुरे की सफाई करते हुये केन के पास से गुजर रही एल टी लाईन के सम्पर्क में आने से उक्त दुर्घटना घटी।			उक्त दुर्घटना में निगम की भूमिका नहीं होने के कारण उक्त प्रकरण में मुआवजा स्वीकृत नहीं किया गया।
6	श्री भावेश पुत्र श्री भूराराम	Public Man	Fatal	17.06.2019	आबूरोड (ग्रामीण)	आबूरोड	विद्युत पोल के स्टेवायर के सम्पर्क में आने से उक्त दुर्घटना घटित हुई।		5,00,000	
7	श्री वरदा राम पुत्र श्री अम्बाराम	Employee	Non Fatal	17.06.19	कालन्दी	कालन्दी	उक्त कर्मचारी द्वारा एल टी लाईन पर कार्य करते समय बैक करंट आने से उक्त दुर्घटना घटी।			पारिरीक अपंगता प्रमाण पत्र प्रस्तुत नहीं किया गया।
8	श्री रवाराम पुत्र श्री दरजा जी	Public Man	Fatal	22.06.19	कालन्दी	कालन्दी	निर्माणधीन मकान के छत पर सरिये से मीटर के बाद वाला वायर बाधा हुआ था, बारिश के मौसम की वजह से नमी होने के कारण करंट प्रभावित हुआ व उक्त दुर्घटना घटित हुई।			Reject by committee

9	श्री मंजित सिंह पुत्र श्री जसवंत सिंह	Public Man	Fatal	17.09.19	सिरोही	सिरोही	मकान के बालकानी के पास से गुजर रही 11 केवी लाईन के सम्पर्क में आने से उक्त दुर्घटना घटित हुई।			Reject by committee
10	श्रीमति जैती देवी पत्नि श्री मोती राम कलबी	Public Man	Fatal	14.09.19	मण्डार	मण्डार	उक्त आमजन अपने कृषि कुए की मोटर चालू करने के दौरान स्टार्टर का बटन दबाते समय केबल में शॉट सर्किट होने से उक्त घातक दुर्घटना घटित हुई।			Enquiry Pending
11	श्री धन्नाराम पुत्र श्री भुरा जी कलबी	Public Man	Fatal	26.09.2019	Mandar	Mandar	कृषि कुएं पर खेत के चारों ओर की गई तारबन्दी में करंट प्रवाहीत होने से उक्त घटना घटित हुई।			
12	श्रीमती राधुदेवी पत्नि श्री मेहरा राम कोली	Public woman	Non-Fatal	03.10.2019	Mandar	Mandar	गॉट सर्किट से एलटी लाइन केवल टूटकर 11केवी लाईन पर गिरने से पोल पर लगी सिंगल फेज केबल में करंट प्रवाहित होने से उक्त दुर्घटना घटित हुई।			
13	श्री श्रवण सिंह पुत्र श्री जीव सिंह	Public man	Fatal	02.11.19	Mandar	Mandar	मकान की छत पर मोबाईल फोन से वार्तालाप के दौरान मकान के पास से गुजर रही लाईन के छूने से घटित हुई।			Enquiry Pending
14	श्री हरि सिंह पुत्र श्री राहु सिंह	Nigam Employee	Non-Fatal	08.11.19	Aburoad (Rural)	Aburoad (Rural)	जी एस एस पर कार्य करते समय 11 केवी बघेरी फीडर के यार्ड से हवाई विद्युत करंट लगने से नीचे गिरने के कारण उक्त दुर्घटना घटित हुई।			Enquiry Pending
15	श्री सुनिल गरसिया पुत्र श्री जालल गरसिया	Public man	Fatal	01.07.19	Sheoganj	Sheoganj	11 केवी लाईन के नीचे टेन्ट लगाते समय पोल को उपर करने पर लाईन के टच होने से करंट लगने से उक्त घातक दुर्घटना घटित हुई।			उक्त दुर्घटना में निगम की भूमिका नहीं होने के कारण उक्त प्रकरण में मुआवजा स्वीकृत नहीं किया गया।
16	श्री अचलाराम पुत्र श्री सवा जी	Public man	Fatal	07.08.19	Sirohi	Sirohi	आवासीय भवन के बाहर निर्माणाधीन दुकानों की छत से गुजर रही 11 केवी डबल सर्किट के लाईन के संपर्क में आने से उक्त घातक दुर्घटना घटित हुई।			उक्त दुर्घटना में निगम की भूमिका नहीं होने के कारण उक्त प्रकरण में मुआवजा स्वीकृत नहीं किया गया।
17	श्री संजय भाई पुत्र श्री वादी लाल	Public man	Fatal	06.01.2020	Mandar	Mandar	तार बंदी व उच्च काम करते वक्त 12 फीट लम्बा पाईप बिजली के संपर्क में आने से दुर्घटना घटीत हुई।			
18	श्री जाकिर मोहम्मद पुत्र श्री रावता खान	डिपार्टमेंटल	घातक	43887	रेवदर	दात्ताणी फीडर	उक्त कर्मचारी द्वारा दात्ताणी फीडर/ लाईन पर विद्युत कार्य करते समय ऊपर से गुजर रही दौलपुरा फीडर की लाईन के संपर्क में आने से करंट लगा व कर्मचारी की मृत्यु हो गई।		14,64,800	